

OHA - Drinking Water Services - Surface Water Quality Data Form County: Jefferson

Cartridge or Bag Filtration 0.54 - Log Month/Year: June 2023

System Name: Camp Tamarack ID#: 41 94114 WTP ID: A

Day	PSI Before Filter 1	PSI After Filter 2	PSI Before Filter 3	PSI After Filter 4	PSID Filters 1 & 2	PSID Filters 3 & 4	PSID When to Change Filter	Daily Turbidity Reading [NTU]
1	79	79	78	74	1	4	30 15	0.266
2	68	68	68	64	0	4	15	0.287
3	71	72	72	67	1	5	15	0.291
4	67	67	67	63	0	4	15	0.332
5	74	74	74	70	0	4	15	0.349
6	83	82	82	77	1	5	15	0.242
7	82	81	81	76	1	5	15	0.517
8	75	76	76	71	1	5	15	0.275
9	83	71	72	67	12	5	15	0.284
10	71	69	72	67	3	5	30 15	0.398
11	71	71	71	66	0	5	15	0.384
12	71	73	73	67	2	6	15	0.290
13	69	71	71	66	2	5	15	0.322
14	84	84	84	79	0	5	15	0.319
15	67	69	69	65	2	4	15	0.286
16	70	71	71	66	1	5	15	0.228
17	65	66	66	62	1	4	15	0.171
18	68	68	68	64	0	4	30 15	0.163
19	65	66	66	63	1	3	15	0.118
20	70	71	71	67	1	4	15	0.123
21	79	79	79	76	0	3	15	0.263
22	75	74	74	71	1	3	15	0.188
23	70	68	70	69	2	1	15	0.191
24	81	76	78	75	5	3	15	0.211
25	73	69	71	68	4	3	15	0.218
26	76	74	76	74	2	2	15	0.361
27	75	72	74	72	3	2	15	0.213
28	75	73	74	72	2	2	15	0.121
29	64	59	62	60	5	2	15	0.179
30	66	63	65	63	3	2	15	0.185
31							30 15	

<b>Cartridge &amp; Bag Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No			
<b>Notes:</b> PSI = pounds per square inch		<b>PRINTED NAME:</b> Charlie Anderson	
PSID = pounds per square inch difference (before filter - after filter)		<b>SIGNATURE:</b>	
PSID When to Change Filter = Refer to manufacturer's specifications at what PSID to change the filter.		<b>DATE:</b> 7/2/23	
		<b>PHONE #:</b> ( ) 541-633-9847	
		<b>CERT #:</b> 41 94114	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values

## OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jefferson

Cartridge or Bag Filtration 0.5  $\mu$ -Log

Month/Year: June 2023

System Name: Camp Tamarack ID#: 41 94114

WTP ID: A

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/	0.8	66	52.8	17.3	7.7	18	Yes	
2/	0.8		52.8	17.2	7.8	18	Yes	
3/	1.0		66	17.9	7.7	18	Yes	
4/	0.8		52.8	18.5	7.7	18	Yes	
5/	0.8		52.8	18.1	7.8	18	Yes	
6/	1.0		66	19.5	7.8	18	Yes	
7/	1.0		66	19.8	7.8	18	Yes	
8/	0.8		52.8	21.1	7.8	<del>18</del> 13	Yes	
9/	0.8		52.8	21.5	7.9	13	Yes	
10/	0.8		52.8	20.8	7.8	13	Yes	
11/	0.6		39.6	20.4	7.8	13	Yes	
12/	0.6	66	39.6	20.1	7.8	13	Yes	
13/	0.6		39.6	20.3	7.7	13	Yes	
14/	0.4		26.4	18.9	7.7	<del>18</del> 17	Yes	
15/	0.4		26.4	16.6	7.9	17	Yes	
16/	0.4		26.4	17.1	7.7	17	Yes	
17/	0.4		26.4	18.5	7.8	17	Yes	
18/	0.4		26.4	16.9	7.8	17	Yes	
19/	0.4		26.4	15.2	7.8	17	Yes	
20/	0.4		26.4	14.3	7.9	<del>17</del> 25	Yes	
21/	1.0		66	13.8	7.9	<del>18</del> 27	Yes	
22/	0.8		52.8	15.3	7.7	<del>18</del> 18	Yes	
23/	1.0		66	17.1	7.7	18	Yes	
24/	1.0		66	18.3	7.9	18	Yes	
25/	0.8		52.8	19.1	7.9	18	Yes	
26/	1.0		66	18.9	7.7	18	Yes	
27/	0.8	66	52.8	19.6	7.8	18	Yes	
28/	1.0		66	20.3	7.8	14	Yes	
29/	1.0		66	21.8	7.8	14	Yes	
30/	1.0		66	21.6	7.9	14	Yes	
31/								

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016 Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)

Return by 10<sup>th</sup> of following month by email, fax or mail to: