

OHA - Drinking Water Services - Surface Water Quality Data Form County: Jefferson

Cartridge or Bag Filtration 0.54 - Log Month/Year: September 2023

System Name: Camp Tamarack ID#: 41 94114 WTP ID: A

Day	PSI Before Filter 1	PSI After Filter 2	PSI Before Filter 3	PSI After Filter 4	PSID Filters 1 & 2	PSID Filters 3 & 4	PSID When to Change Filter	Daily Turbidity Reading [NTU]
1	66	64	67	65	2	2	30 15	0.109
2	70	68	72	68	2	4	15	0.240
3	74	71	75	72	3	3	15	0.084
4	77	74	76	72	3	4	15	0.091
5	69	66	70	67	3	3	15	0.072
6	78	75	79	76	3	3	15	0.119
7	66	63	65	61	3	4	15	0.163
8	72	70	74	70	2	4	15	0.159
9	66	63	66	63	3	3	15	0.077
10	76	68	72	67	2	5	15	0.117
11	80	75	78	74	5	4	15	0.221
12	66	61	64	60	5	4	15	0.082
13	82	75	78	73	7	5	15	0.085
14	72	65	68	64	7	4	30 15	0.108
15	72	67	71	67	5	4	15	0.095
16	69	56	61	56	13	5	15	0.084
17	66	64	66	64	2	2	15	0.119
18	82	72	75	70	10	5	15	0.101
19	81	77	80	77	4	3	15	0.073
20	70	64	66	64	6	2	15	0.087
21	72	57	61	56	15	5	15	0.089
22	66	50	54	50	16	4	15	0.077
23	79	61	65	60	18	5	15	0.102
24	61	41	47	42	20	5	15	0.082
25	70	66	70	65	4	5	30 15	0.063
26	81	80	83	75	1	8	15	0.070
27	77	76	78	69	1	9	15	0.081
28	75	74	76	63	1	13	15	0.067
29	80	79	82	70	1	12	15	0.069
30	67	66	69	56	1	13	15	0.102
31							15	

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No
Notes: PSI = pounds per square inch	PRINTED NAME: <i>Chylic Aholisa</i>	
PSID = pounds per square inch difference (before filter - after filter)	SIGNATURE: <i>[Signature]</i>	DATE: 10/2/23
PSID When to Change Filter = Refer to manufacturer's specifications at what PSID to change the filter.	511-633-9847	94114
	PHONE #: ()	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values

OHA - Drinking Water Services - Surface Water Quality Data Form | County: Jefferson

Cartridge or Bag Filtration 0.5 μ -Log | Month/Year: September 2023

System Name: Camp Tamarack ID#: 41 94114 | WTP ID: A

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/	0.4	66	26.4 ^{26.4}	19.1	8.2	20	Yes	
2/	0.4		26.4	18.8	8.1	20	Yes	
3/	0.4		26.4	19.2	8.1	20	Yes	
4/	0.4		26.4	19.0	8.1	20	Yes	
5/	0.4		26.4	17.8	8.0	17	Yes	
6/	0.8		52.8	18.2	8.0	18	Yes	
7/	0.8		52.8	18.6	7.9	18	Yes	
8/	0.4		26.4	18.2	7.9	17	Yes	
9/	1.2		79.2	19.4	8.0	19	Yes	
10/	0.8		52.8	20.6	8.0	13	Yes	
11/	0.8		52.8	19.4	8.0	18	Yes	
12/	0.8		52.8	19.9	7.9	18	Yes	
13/	1.2	66	79.2	19.2	8.1	22	Yes	
14/	1.2		79.2	19.4	8.0	19	Yes	
15/	0.6		39.6	18.9	8.0	17	Yes	
16/	0.4		26.4	18.8	8.1	20	Yes	
17/	0.6		39.6	19.3	7.9	17	Yes	
18/	0.4		26.4	19.7	7.9	17	Yes	
19/	0.4		26.4	19.6	8.0	17	Yes	
20/	0.6		39.6	19.1	8.0	17	Yes	
21/	0.8		52.8	18.4	7.9	18	Yes	
22/	0.6		39.6	17.7	7.9	17	Yes	
23/	0.6		39.6	16.9	8.0	17	Yes	
24/	0.4		26.4	16.2	8.0	17	Yes	
25/	0.4	66	26.4	15.9	7.9	17	Yes	
26/	0.4		26.4	16.5	7.8	17	Yes	
27/	0.4		26.4	16.1	7.9	17	Yes	
28/	0.4		26.4	16.3	7.9	17	Yes	
29/	0.8		52.8	16.4	7.8	18	Yes	
30/	0.8		52.8	14.4	7.9	20 ²⁶	Yes	
31/	0.8		52.8	13.7	7.9	20	Yes	

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to: