

OHA - Drinking Water Services - Surface Water Quality Data Form County: Jefferson

Cartridge or Bag Filtration 0.54 - Log Month/Year: April 2024

System Name: Camp Tamarack ID#: 41 94114 WTP ID: A

Day	PSI Before Filter 1	PSI After Filter 2	PSI Before Filter 3	PSI After Filter 4	PSID Filters 1 & 2	PSID Filters 3 & 4	PSID When to Change Filter	Daily Turbidity Reading [NTU]
1	80	80	81	79	0	2	15	0.087
2	66	65	68	66	1	2	15	0.101
3	70	69	72	69	1	3	15	0.082
4	70	69	71	69	1	2	15	0.088
5	68	67	70	67	1	3	15	0.103
6	80	79	80	78	1	2	15	0.090
7	66	64	67	65	2	2	15	0.151
8	80	79	81	78	1	3	15	0.090
9	76	75	76	74	1	2	15	0.083
10	69	67	71	67	2	4	15	0.082
11	70	68	71	68	2	3	15	0.089
12	80	76	80	76	4	4	15	0.114
13	73	70	72	68	3	4	15	0.093
14	70	67	71	67	3	4	15	0.077
15	71	68	71	67	3	4	15	0.085
16	69	66	69	66	3	3	15	0.131
17	80	76	79	75	4	4	15	0.079
18	78	75	77	73	3	4	15	0.095
19	71	66	69	65	5	4	15	0.092
20	83	76	79	75	7	4	15	0.080
21	68	63	66	62	5	4	15	0.084
22	70	65	68	63	5	5	15	0.091
23	72	65	69	66	7	3	15	0.103
24	75	68	72	67	7	5	15	0.086
25	66	59	62	57	7	5	15	0.095
26	70	58	61	58	12	3	15	0.096
27	81	71	75	71	10	4	15	0.125
28	72	62	68	63	10	5	15	0.092
29	69	57	61	56	12	5	15	0.090
30	78	67	72	66	11	6	15	0.097
31							15	

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l? <input type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch	PRINTED NAME: <i>Charlie A. [Signature]</i>	
PSID = pounds per square inch difference (before filter - after filter)	SIGNATURE: <i>[Signature]</i>	DATE: 4/30/24
PSID When to Change Filter = Refer to manufacturer's specifications at what PSID to change the filter.	541-633-9415	94114
	PHONE #: ()	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values

OHA - Drinking Water Services - Surface Water Quality Data Form | County: Jefferson

Cartridge or Bag Filtration **0.5 - Log** | Month/Year: **April 2024**

System Name: **Camp Tamarack** ID#: **41 94114** | WTP ID: **A**

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1/	1.0	66	66	10	8.5	33	Yes	
2/	1.0		66	5	8.0	36	Yes	
3/	1.2		79.2	10	8.0	23	Yes	
4/	1.2		79.2	5	8.0	37	Yes	
5/	1.4		92.4	5	8.0	38	Yes	
6/	1.6		105.6	5	8.0	39	Yes	
7/	0.8		52.8	10	7.5	22	Yes	
8/	0.6		39.6	10	7.5	21	Yes	
9/	0.8	66	52.8	10	7.5	22	Yes	
10/	0.8		52.8	10	7.5	22	Yes	
11/	0.8		52.8	10	7.5	22	Yes	
12/	1.2		79.2	10	7.5	23	Yes	
13/	1.0		66	10	8.0	27	Yes	
14/	1.0		66	10	8.0	27	Yes	
15/	1.0		66	10	8.0	27	Yes	
16/	1.2		79.2	10	8.0	28	Yes	
17/	1.0		66	10	8.0	27	Yes	
18/	1.0		66	10	8.0	27	Yes	
19/	1.2	66	79.2	10	8.0	28	Yes	
20/	1.0		66	10	8.0	27	Yes	
21/	1.2		79.2	10	8.0	28	Yes	
22/	1.4		92.4	10	8.0	28	Yes	
23/	1.0		66	10	8.0	27	Yes	
24/	0.6		39.6	10	8.0	26	Yes	
25/	0.6		39.6	15	8.0	17	Yes	
26/	0.6		39.6	10	8.0	26	Yes	
27/	0.6		39.6	10	8.0	26	Yes	
28/	1.2		79.2	10	8.0	28	Yes	
29/	1.2		79.2	10	8.0	28	Yes	
30/	0.6		39.6	10	8.0	26	Yes	
31/		66						

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised August 2016 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

Return by 10th of following month by email, fax or mail to: