

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jefferson

Cartridge or Bag Filtration

Month/Year: JULY 2025

System Name:	Camp Tamarack			ID#:	41 94144	WTP ID:	TP:	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]			
1	70	50	20	30	.171			
2	65	45	20	30	.108			
3	75	70	5	30	CHANGE FILTER GET .138			
4	70	65	5	30	.116			
5	65	60	5	30	.203			
6	75	69	6	30	.107			
7	80	70	10	30	.124			
8	78	66	12	30	.154			
9	77	65	12	30	.151			
10	76	64	12	30	.143			
11	75	62	13	30	.087			
12	63	57	6	30	.101			
13	69	51	18	30	.161			
14	61	55	6	30	.101			
15	70	70	6	30	.146			
16	69	64	5	30	.114			
17	72	65	7	30	.138			
18	70	63	7	30	.104			
19	74	60	14	30	.133			
20	65	48	17	30	.182			
21	60	55	5	30	.117			
22	68	64	4	30	.183			
23	71	67	4	30	.131			
24	73	67	6	30	.123			
25	72	66	6	30	.138			
26	76	71	5	30	.218			
27	69	63	6	30	.134			
28	70	60	10	30	.149			
29	79	66	13	30	.151			
30	80	55	25	30	.149			
31	66	63	3	30	.132			

Cartridge & Bag Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU?

Yes / No

CT's met everyday?
(see back)All Cl2 residual at entry point ≥ 0.2 mg/l?All daily turbidity readings ≤ 5 NTU?

Yes / No

Yes / No

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME:

SIGNATURE:

DATE:

PHONE #:

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System
Name:

Camp Tamarack

ID#: 41 94144

Month/Year:

July
2025Disinfection
Gardia Log
Inactiv:

0.5

Date	Cl ₂ Residual (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C x T	[° C]		tables	Yes / No	[GPM]
1	1.06	66	66	19.5	7.1	13	YES	1030am
2	1.13	66	79.5	21.4	7	13	YES	11:30am
3	1.38	66	92.4	21.1	7.1	10	YES	10am
4	2.12	66	145.2	20.9	7.5	13	YES	830am
5	2.13	66	145.2	18	7.2	17	YES	7:45am
6	2.13	66	145.2	19.2	7.1	11	YES	10am
7	2.17	66	145.2	21.3	7.1	11	YES	10am
8	1.30	66	92.4	22.4	7.3	12	YES	10am
9	1.81	66	118.8	22.1	7.3	12	YES	10am
10	1.95	66	132	21.3	7.1	13	YES	10am
11	2.10	66	145.2	21.1	7.4	13	YES	630am
12	1.11	66	79.2	20	7.2	12	YES	8am
13	.96	66	66	23.3	7.0	9	YES	11am
14	1.21	66	79.2	23.9	7.2	12	YES	1030am
15	.46	66	30.36	23.3	7.2	10	YES	10am
16	1.20	66	79.2	22.3	7.2	12	YES	1030am
17	1.63	66	118.8	23.4	7.3	17	YES	9:30am
18	1.48	66	105.6	21	7.3	12	YES	6am
19	1.48	66	105.6	22	7.2	12	YES	6am
20	1.46	66	105.6	22	7.1	12	YES	1030am
21	1.27	66	92.4	21.9	7.0	10	YES	930am
22	.97	66	39.6	21.7	7.3	11	YES	9:30am
23	.60	66	39.6	21.6	7.1	14	YES	10am
24	1.1	66	79.2	21.6	7.2	12	YES	10am
25	1.49	66	105.6	23.0	7.4	12	YES	1pm
26	.87	66	66	20.0	7.1	11	YES	930am
27	.82	66	66	20.0	7.1	11	YES	10am
28	1.01	66	79.2	22.7	7.1	12	YES	9am
29	1.11	66	79.2	22.5	7.2	12	YES	10:30
30	1.68	66	118.8	22.7	7.3	12	YES	10am
31	1.57	66	105.6	22.4	7.2	12	YES	930am

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Rev. April 18, 2025

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14450, Portland, OR 97293-0350

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System
Name:

Camp Tamarack

ID#: 41 94144

Month/Year:

July
2025Disinfection
Gardla Log
Inactiv:

0.5

Date	Cl ₂ Residual (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C x T	[°C]		tables	Yes / No	[GPM]
1	1.06	66	66	19.5	7.1	13	YES	1030am
2	1.13	66	79.5	21.4	7	13	YES	11:30am
3	1.38	66	92.4	21.1	7.1	10	YES	10am
4	2.12	66	145.2	20.9	7.5	13	YES	830am
5	2.13	66	145.2	18	7.2	17	YES	7:45am
6	2.13	66	145.2	19.2	7.1	11	YES	10:am
7	2.17	66	145.2	21.3	7.1	11	YES	10am
8	1.30	66	92.4	22.4	7.3	12	YES	10am
9	1.81	66	118.8	22.1	7.3	12	YES	10am
10	1.95	66	132	21.3	7.1	13	YES	10am
11	2.10	66	145.2	21.1	7.4	13	YES	630am
12	1.11	66	79.2	20	7.2	12	YES	8am
13	.96	66	66	23.3	7.0	9	YES	11am
14	1.21	66	79.2	23.9	7.2	12	YES	1030am
15	.46	66	30.36	23.3	7.2	10	YES	10am
16	1.20	66	79.2	22.3	7.2	12	YES	1030am
17	1.63	66	118.8	23.4	7.3	17	YES	9:30am
18	1.48	66	105.6	21	7.3	12	YES	6am
19	1.48	66	105.6	22	7.2	12	YES	6am
20	1.46	66	105.6	22	7.1	12	YES	1030am
21	1.27	66	92.4	21.9	7.0	10	YES	930am
22	1.47	66	39.6	21.7	7.3	11	YES	9:30am
23	.60	66	37.6	21.6	7.1	14	YES	10am
24	1.1	66	79.2	21.6	7.2	12	YES	10am
25	1.49	66	105.6	23.0	7.4	12	YES	1pm
26	.87	66	66	20.0	7.1	11	YES	930am
27	.82	66	66	20.0	7.1	11	YES	10am
28	1.01	66	79.2	22.7	7.1	12	YES	9am
29	1.11	66	79.2	22.5	7.2	12	YES	10:30
30	1.68	66	118.8	22.7	7.3	12	YES	10am
31	1.57	66	105.6	22.4	7.2	12	YES	930am

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Rev. April 18, 2025

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14450, Portland, OR 97293-0350