

Cartridge or Bag Filtration

Month/Year: AUGUST 2025

System Name: Camp Tamarack		ID#: 41 94144		WTP ID: TP- A	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]
1	69	66	3	30	.153
2	80	76	4	30	.145
3	68	63	5	30	.166
4	71 71	64	7	30	.155
5	69	54	13	30	.153
6	74	69	5	30	.163
7	72	68	4	30	.167
8	76	71	5	30	.177
9	78	71	7	30	.166
10	79	67	12	30	.167
11	74	46	28	30	.173
12	80	76	4	30	.216
13	64	60	4	30	.186
14	74	67	7	30	.179
15	70	61	9	30	.166
16	65	47	18	30	.186
17	70	66	4	30	.228
18	67	61	6	30	.176
19	79	62	17	30	.180
20	77	38	39	30	.180
21	72	68	4	30	.186
22	71	66	5	30	.185
23	67	62	5	30	.196
24	66	61	5	30	.179
25	70	64	6	30	.174
26	74	64	8	30	.295
27	76	70	6	30	.171
28	80	73	7	30	.163
29	76	58	18	30	.180
30	80	60	20	30	.176
31	63	57	6	30	.171

Cartridge & Bag Filtration

95% of daily turbidity readings $\leq$ 1 NTU?

Yes/No

All daily turbidity readings $\leq$ 5 NTU?

Yes/No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes/No

All Cl2 residual at entry point $\geq$ 0.2 mg/L?

Yes/No

PRINTED NAME:

SIGNATURE:

DATE: 9/1/20

PHONE #:

CERT #: 94144

Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP.: A

System
Name:

Camp Tamarack

ID#: 41 94144

Month/Year:

August
2025Disinfection
Giardia Log
Inactiv:

0.5

Date	Cl ₂ Residual (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C x T	[° C]		tables	Yes / No	[GPM]
1	.75	66	52.8	21.5	7.4	11	YES	6 am
2	1.35	66	92.4	20.4	7.3	12	YES	7 am
3	1.61	66	118.8	22.2	7.1	12	YES	10 am
4	1.58	66	105.6	22.2	7.1	12	YES	930 am
5	1.53	66	105.6	23.1	7.2	12	YES	1030 am
6	.66	66	52.8	22.2	7.1	11	YES	10 am
7	1.03	66	92.4	21.0	7.1	12	YES	945 am
8	1.25	66	92.4	21.1	7.1	12	YES	530 am
9	1.04	66	79.2	20.1	7.3	12	YES	8 am
10	1.43	66	105.6	22.3	7.1	12	YES	10 am
11	1.60	66	105.6	23.1	7.1	12	YES	930 am
12	1.17	66	79.2	23.2	7.2	12	YES	930 am
13	1.12	66	79.2	22.2	7.2	12	YES	1030 am
14	1.74	66	118.8	23	7.1	12	YES	10 am
15	1.29	66	92.4	21.3	7.1	12	YES	930 am
16	.86	66	66	20.1	7.1	11	YES	830 am
17	.42	66	39.6	20.2	7.2	11	YES	9 am
18	1.25	66	92.4	23.2	7.2	12	YES	11 am
19	1.53	66	105.6	21.1	7.1	12	YES	1030 am
20	1.49	66	105.6	20.2	7.3	12	YES	530 am
21	.47	66	39.6	20.1	7.3	11	YES	830 am
22	.78	66	52.8	19.3	7.2	15	YES	8 am
23	.97	66	66	18.4	7.2	15	YES	730 am
24	.98	66	66	20.2	7.2	11	YES	830 am
25	1.10	66	79.2	21.1	7.1	12	YES	830 am
26	1.09	66	79.2	20.1	7.1	12	YES	8 am
27	.93	66	66	22.2	7.2	11	YES	730 am
28	.97	66	66	21.2	7.1	11	YES	730 am
29	1.18	66	79.2	23.1	7.1	12	YES	9 am
30	1.03	66	79.2	23.2	7.2	12	YES	930 am
31	1.04	66	79.2	24.3	7.3	12	YES	11 am

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Rev. April 18, 2025

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14450, Portland, OR 97293-0350