

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jefferson

Cartridge or Bag Filtration

Month/Year: OCT 2025

System Name:	Camp Tamarack			ID#: 41 94144	WTP ID: TP- A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]
1	74	70	4	30	.218
2	67	63	4	30	.221
3	75	70	5	30	.204
4	71	67	4	30	.227
5	66	62	4	30	.252
6	74	68	6	30	.198
7	76	66	10	30	.187
8	64	61	3	30	.218
9	65	62	3	30	.246
10	71	67	4	30	.302
11	67	63	4	30	.331
12	82	78	4	30	.318
13	66	62	4	30	.214
14	68	61	7	30	.234
15	74	60	14	30	.220
16	75	56	19	30	.222
17	63	60	3	30	.225
18	71	68	3	30	.216
19	67	64	3	30	.226
20	70	65	5	30	.207
21	70	64	6	30	.195
22	80	70	10	30	.181
23	80	60	20	30	.193
24	70	46	24	30	.180
25	78	51	27	30	.256
26	80	78	2	30	.188
27	65	61	4	30	.216
28	67	63	4	30	.207
29	72	67	5	30	.204
30	72	67	5	30	.202
31	69	64	5	30	.212

Cartridge & Bag Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU?

Yes / No

CT's met everyday?
(see back)All Cl2 residual at entry point ≥ 0.2 mg/l?All daily turbidity readings ≤ 5 NTU?

Yes / No

Yes / No

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: *Shirley Anderson*SIGNATURE: *[Signature]*

DATE: 10/31/25

PHONE #: (541) 651-9647

CERT #: 194194

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System
Name:

Camp Tamarack

ID#: 41 94144

Month/Year:

OCT
2025Disinfection
Giardia Log
Inactiv:

0.5

Date	Cl ₂ Residual (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C x T	[° C]		tables	Yes / No	[GPM]
1	0.62	66	52.8	20.2	7.0	11	465	11 am
2	1.15	66	79.2	20.1	7.1	12	465	10 am
3	1.75	66	118.8	19.3	7.5	16	465	9 am
4	1.72	66	118.8	15.9	7.5	16	465	10 am
5	1.43	66	105.6	14.8	7.5	24	465	830 am
6	1.30	66	92.4	14.8	7.4	23	465	1030 am
7	1.4	66	92.4	15.4	7.4	16	465	930 am
8	1.36	66	92.4	16.6	7.4	16	465	1030 am
9	0.41	66	39.6	18.7	7.5	14	465	930 am
10	1.19	66	79.2	15.3	7.5	15	465	230 pm
11	1.44	66	105.6	14.1	7.6	29	465	9 am
12	1.49	66	105.6	12.9	7.6	29	465	9 am
13	1.67	66	118.8	13.8	7.5	25	465	930 am
14	1.64	66	118.8	14.1	7.5	25	465	1030 am
15	1.49	66	105.6	15.5	7.5	16	465	11 am
16	1.42	66	105.6	14.8	7.5	24	465	930 am
17	1.40	66	92.4	15.9	7.6	19	465	3 pm
18	0.37	66	26.4	15.2	7.8	12	465	130 pm
19	0.58	66	39.6	14.6	7.6	26	465	830 am
20	0.92	66	66	14.4	7.7	27	465	730 am
21	1.41	66	105.6	13.9	7.7	29	465	930 am
22	1.66	66	118.8	14.2	7.6	30	465	10 am
23	1.29	66	92.4	14.3	7.6	28	465	10 am
24	1.58	66	105.6	15.0	7.7	19	465	830 am
25	1.45	66	105.6	13.7	7.7	29	465	930 am
26	1.22	66	92.4	11.4	7.8	28	465	1 pm
27	0.55	66	39.6	12.7	7.8	26	465	930 am
28	1.06	66	79.2	14.4	7.6	28	465	10 am
29	1.20	66	79.2	13.9	7.6	28	465	2 pm
30	1.54	66	105.6	14.4	7.7	29	465	11 am
31	1.46	66	105.6	14.1	7.8	29	465	10 am

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Rev. April 18, 2025

Return by 10th of following month by email, fax, or mail to:

dwp.dmca@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14450, Portland, OR 97293-0350