

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:  
Cartridge or Bag Filtration**

System Name: Hamber Quick Stop ID #: 94157 WTP: A Month/Year: Feb. '23

| DAY | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading (NTU) | Highest Reading of the Day (NTU) |
|-----|-------------------|------------------|------|----------------------------|-------------------------------|----------------------------------|
| 1   | 28                | 24               | 4    | 12                         | .24                           |                                  |
| 2   | 28                | 24               | 4    |                            | .25                           |                                  |
| 3   | 28                | 24               | 4    |                            | .24                           |                                  |
| 4   | 28                | 24               | 4    |                            | .26                           |                                  |
| 5   | 28                | 24               | 4    |                            | .22                           |                                  |
| 6   | 28                | 24               | 4    |                            | .27                           |                                  |
| 7   | 28                | 24               | 4    |                            | .25                           |                                  |
| 8   | 28                | 24               | 4    |                            | .24                           |                                  |
| 9   | 28                | 24               | 4    |                            | .24                           |                                  |
| 10  | 28                | 24               | 4    |                            | .24                           |                                  |
| 11  | 28                | 24               | 4    |                            | .26                           |                                  |
| 12  | 28                | 24               | 4    |                            | .27                           |                                  |
| 13  | 28                | 24               | 4    |                            | .23                           |                                  |
| 14  | 28                | 24               | 4    |                            | .25                           |                                  |
| 15  | 28                | 24               | 4    |                            | .24                           |                                  |
| 16  | 28                | 24               | 4    |                            | .24                           |                                  |
| 17  | 28                | 24               | 4    |                            | .27                           |                                  |
| 18  | 28                | 24               | 4    |                            | .27                           |                                  |
| 19  | 28                | 24               | 4    |                            | .25                           |                                  |
| 20  | 26                | 22               | 4    |                            | .26                           |                                  |
| 21  | 26                | 22               | 4    |                            | .25                           |                                  |
| 22  | 26                | 22               | 4    |                            | .23                           |                                  |
| 23  | 26                | 22               | 4    |                            | .22                           |                                  |
| 24  | 26                | 22               | 4    |                            | .22                           |                                  |
| 25  | 26                | 22               | 4    |                            | .24                           |                                  |
| 26  | 26                | 22               | 4    |                            | .23                           |                                  |
| 27  | 26                | 22               | 4    |                            | .24                           |                                  |
| 28  | 26                | 22               | 4    |                            | .25                           |                                  |
| 29  |                   |                  |      |                            |                               |                                  |
| 30  |                   |                  |      |                            |                               |                                  |
| 31  |                   |                  |      |                            |                               |                                  |

|  |  |  |  |
|--|--|--|--|
| <b>Cartridge Filtration</b>  |  | <b>Monthly Summary (Answer Yes or No)</b>                              |  |
| 95% of daily turbidity readings ≤ 1 NTU?<br>All daily turbidity readings ≤ 5 NTU?  | <input checked="" type="checkbox"/> Yes<br><input type="checkbox"/> No | CT's met everyday? (see back)  | All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?                |
|  |  | <input checked="" type="checkbox"/> Yes<br><input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes<br><input type="checkbox"/> No |
| Notes: PSI = pounds per square inch<br>PSD = pounds per square inch difference (before filter - after filter)<br>PSD When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSD. |  | PRINTED NAME: <u>Ludak Winkler</u>                                     | DATE: <u>2-28-23</u>   |
|  |  | SIGNATURE: <u>[Signature]</u>  |  |
|  |  | PHONE: <u>503 738-0302</u>   | CERT #:  |

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

**OHA - Drinking Water Program -- Surface Water Quality Data Form**

System Name: Hamlet Quick Stop ID#: 94157 WTP: A Month/Year: Feb. '23

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup><br>[ppm or mg/L] | Contact Time (T)<br>[minutes] | Actual CT<br>CXT | Temp<br>[°C] | pH  | Required CT<br>Use tables | CT Met? <sup>2</sup><br>Yes / No | Peak Hourly Demand Flow<br>[GPM] |
|-------------|--|-------------------------------|------------------|--------------|-----|---------------------------|----------------------------------|----------------------------------|
| 1/          | 0.6  | 15                            | 9                |              |     | 6                         |                                  | 5 (Flow restricted)              |
| 2/          | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 3/          | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 4/          | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 5/          | 0.6  |                               | 9                |              | 5.6 |                           |                                  |                                  |
| 6/          | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 7/          | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 8/          | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 9/          | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 10/         | 0.6  |                               | 9                |              | 5.6 |                           |                                  |                                  |
| 11/         | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 12/         | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 13/         | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 14/         | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 15/         | 0.6  |                               | 9                |              | 5.6 |                           |                                  |                                  |
| 16/         | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 17/         | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 18/         | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 19/         | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 20/         | 0.6  |                               | 9                |              | 5.6 |                           |                                  |                                  |
| 21/         | 0.6  |                               | 9                |              |     |                           |                                  |                                  |
| 22/         | 0.7  |                               | 10.5             |              |     |                           |                                  |                                  |
| 23/         | 0.7  |                               | 10.5             |              |     |                           |                                  |                                  |
| 24/         | 0.7  |                               | 10.5             |              |     |                           |                                  |                                  |
| 25/         | 0.7  |                               | 10.5             |              | 5.7 |                           |                                  |                                  |
| 26/         | 0.7  |                               | 10.5             |              |     |                           |                                  |                                  |
| 27/         | 0.7  |                               | 10.5             |              |     |                           |                                  |                                  |
| 28/         | 0.7  |                               | 10.5             |              |     |                           |                                  |                                  |
| 29/         |  |                               |                  |              |     |                           |                                  |                                  |
| 30/         |  |                               |                  |              |     |                           |                                  |                                  |
| 31/         |  |                               |                  |              |     |                           |                                  |                                  |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day. Revised February 2012  
 Download form at: [public.health.wa.gov/HealthyEnvironment/DrinkingWater/Monitoring/Documents/sub-criteria.pdf](http://public.health.wa.gov/HealthyEnvironment/DrinkingWater/Monitoring/Documents/sub-criteria.pdf)