

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:
Cartridge or Bag Filtration

System Name: Hanjet Quick Stop

ID #: 94157 WTP: A

Month/Year: May '24

DAY	PSI Before Filter	PSI After Filter	PSD	PSD When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the Day (NTU)
1	28	24	4	12	23	24
2	28	24	4	-	23	23
3	28	24	4	-	24	24
4	28	24	4	-	22	22
5	28	24	4	-	25	25
6	28	24	4	-	24	24
7	28	24	4	-	26	26
8	28	24	4	-	25	25
9	28	24	4	-	24	24
10	28	24	4	-	25	25
11	28	24	4	-	23	23
12	28	24	4	-	25	25
13	28	24	4	-	25	25
14	28	24	4	-	23	23
15	28	24	4	-	22	22
16	28	24	4	-	23	23
17	28	24	4	-	24	24
18	28	24	4	-	24	24
19	28	24	4	-	21	21
20	28	24	4	-	22	22
21	28	24	4	-	25	25
22	28	24	4	-	23	23
23	28	24	4	-	22	22
24	28	24	4	-	25	25
25	28	24	4	-	24	24
26	28	24	4	-	24	24
27	26	22	4	-	25	25
28	26	22	4	-	23	23
29	26	22	4	-	25	25
30	26	22	4	-	22	22
31	26	22	4	-	22	22

Monthly Summary (Answer Yes or No)

Cartridge Filtration

95% of daily turbidity readings ≤ 1 NTU?
 Yes No
 All daily turbidity readings ≤ 5 NTU?
 Yes No

CT's met everyday? (see back)
 Yes No

All Cl₂ residual at entry point ≥ 0.2 mg/l?
 Yes No

Note: PSI = pounds per square inch

PSD = pounds per square inch difference
 (before filter - after filter)

PSD When to Change Filter = Manufacturer's
 recommendation; may need to look in manual for
 manufacturer's specifications when to change
 the filter, at what PSD.

PRINTED NAME: Ludek Wichter

SIGNATURE: Ludek Wichter

DATE: 5/31/24

PHONE #: (603) 738-0302

CERT #:

OHA - Drinking Water Program – Surface Water Quality Data Form

System Name: Hawley Quick Stop ID #: 94157 WTP #: A Month/Year: May 24

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1/	0.6	15	9			6		5 (Flow restricted)
2/	0.6		9			7		
3/	0.6		9		5.6	7		
4/	0.6		9					
5/	0.6		9					
6/	0.6		9					
7/	0.6		9					
8/	0.6		9					
9/	0.6		9					
10/	0.6		9		5.6			
11/	0.6		9					
12/	0.6		9					
13/	0.6		9					
14/	0.6		9					
15/	0.6		9					
16/	0.6		9					
17/	0.6		9		5.6			
18/	0.6		9					
19/	0.6		9					
20/	0.6		9					
21/	0.6		9					
22/	0.6		9					
23/	0.6		9		5.6			
24/	0.6		9					
25/	0.6		9					
26/	0.6		9					
27/	0.7		10.5					
28/	0.7		10.5					
29/	0.7		10.5		5.7			
30/	0.7		10.5					
31/	0.7		10.5					

² If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWaterMonitoring/Documents/fresh-castlog.xls