

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Cartridge or Bag Filtration

System Name: Hand Jet Quick Stop

ID #: 94157 WTP: A

Month/Year: Apr. '25

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the Day (NTU)
1	28	24	4	12	.24	
2	28	24	4		.25	
3	28	24	4		.24	
4	28	24	4		.23	
5	28	24	4		.25	
6	28	24	4		.26	
7	28	24	4		.24	
8	28	24	4		.25	
9	28	24	4		.23	
10	28	24	4		.23	
11	28	24	4		.24	
12	28	24	4		.24	
13	28	24	4		.22	
14	28	24	4		.23	
15	28	24	4		.23	
16	28	24	4		.24	
17	28	24	4		.26	
18	28	24	4		.25	
19	28	24	4		.23	
20	28	22	6		.24	
21	28	22	6		.25	
22	28	22	6		.24	
23	28	22	6		.24	
24	28	22	6		.23	
25	28	22	6		.24	
26	28	22	6		.22	
27	28	22	6		.25	
28	28	22	6		.24	
29	28	22	6		.23	
30	28	22	6		.23	
31						

Cartridge Filtration

95% of daily turbidity readings ≤ 1 NTU?
All daily turbidity readings ≤ 5 NTU?

Yes No
Yes No

Notes: PSI = pounds per square inch
PSID = pounds per square inch difference
(before filter - after filter)
PSID When to Change Filter = Manufacturer's
recommendation; may need to look to manual for
manufacturer's specifications when to change
the filter, at what PSID.

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)
Yes No

All Cl₂ residual at entry point ≥ 0.2 mg/l?
Yes No

PRINTED NAME: Ludak Winkler

SIGNATURE: [Signature]

DATE: 4-30-25

PHONE #: 503) 728-0302

CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings maximum.

OHA - Drinking Water Program -- Surface Water Quality Data Form

System Name:

Hamlet Quick Stop

ID#:

94157

WTP:

A

Month/Year:

Apr. 25

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C x T	Temp [°C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1/	0.6	15	9			6		5 (Flow restrictor)
2/	0.6		9					
3/	0.6		9		5.4			
4/	0.6		9					
5/	0.6		9					
6/	0.6		9					
7/	0.6		9					
8/	0.6		9					
9/	0.6		9		5.4			
10/	0.6		9					
11/	0.6		9					
12/	0.6		9					
13/	0.6		9					
14/	0.6		9		5.4			
15/	0.6		9					
16/	0.6		9					
17/	0.6		9					
18/	0.6		9					
19/	0.6		9		5.2			
20/	0.6		9					
21/	0.5		7.5					
22/	0.5		7.5					
23/	0.5		7.5		5.3			
24/	0.5		7.5					
25/	0.5		7.5					
26/	0.5		7.5					
27/	0.5		7.5					
28/	0.5		7.5		5.3			
29/	0.5		7.5					
30/	0.5		7.5					
31/								

If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.

Download form at:

public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Forms/Forms/Documents/surb-cartridge.pdf

Revised February 2012