

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Cartridge or Bag Filtration

System Name: Hu-let Quick Stop ID# 94157 WTP: A Month/Year: Aug. 25

DAY	PSI Before Filter	PSI After Filter	PSD	PSD When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day [NTU]
1	28	24	4	12	24	
2	28	24	4		25	
3	28	24	4		24	
4	28	24	4		23	
5	28	24	4		22	
6	28	24	4		23	
7	28	24	4		25	
8	28	24	4		26	
9	28	24	4		25	
10	28	24	4		22	
11	28	24	4		23	
12	28	24	4		24	
13	28	24	4		26	
14	28	24	4		25	
15	28	24	4		25	
16	28	24	4		24	
17	28	24	4		24	
18	28	24	4		25	
19	28	24	4		24	
20	28	22	6		22	
21	28	22	6		23	
22	28	22	6		24	
23	28	22	6		25	
24	28	22	6		23	
25	28	22	6		25	
26	28	22	6		23	
27	28	22	6		24	
28	28	22	6		25	
29	28	22	6		24	
30	28	22	6		26	
31	28	22	6		24	

Cartridge Filtration 95% of daily turbidity readings ≤ 1 NTU? ☒ Yes ☐ No All daily turbidity readings ≤ 5 NTU? ☒ Yes ☐ No		Monthly Summary (Answer Yes or No) CTe met everyday? (see back) ☒ Yes ☐ No All C ₂ residual at entry point ≥ 0.2 mg/l? ☒ Yes ☐ No	
Notes: PSI = pounds per square inch PSD = pounds per square inch difference (before filter - after filter) PSD When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSD.		PRINTED NAME: <u>Ludak Winkler</u> SIGNATURE: <u>[Signature]</u> DATE: <u>9-1-25</u> PHONE #: <u>(503) 738-0102</u> CERT #: _____	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hamlet Quick Stop ID# 94157 WTP: A Month/Year: Aug. '21

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	0.6	15	9			6		5 (Flow restrictor)
2/	0.6		9					
3/	0.6		9					
4/	0.6		9		5.3			
5/	0.6		9					
6/	0.6		9					
7/	0.6		9					
8/	0.6		9					
9/	0.6		9					
10/	0.6		9					
11/	0.6		9		5.3			
12/	0.6		9					
13/	0.6		9					
14/	0.6		9					
15/	0.6		9					
16/	0.6		9		5.3			
17/	0.6		9					
18/	0.6		9					
19/	0.6		9					
20/	0.6		9					
21/	0.6		9					
22/	0.6		9		5.4			
23/	0.6		9					
24/	0.7		10.5					
25/	0.7		10.5					
26/	0.7		10.5					
27/	0.7		10.5					
28/	0.7		10.5		5.4			
29/	0.7		10.5					
30/	0.7		10.5					
31/	0.7	✓	10.5			✓		✓

² If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day. Revised February 2012
Download form at: public.health.oregon.gov/healthyEnvironments/DrinkingWater/files/DrinkingWaterForms/Documents/wh-ccr-001a.pdf