

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: ☐  
 Cartridge or Bag Filtration

System Name: Harvest Quick Stop ID #: 94157 WTP: A Month/Year: Mar. '26

DAY	PSI Before Filter	PSI After Filter	PSD	PSD When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the Day (NTU)
1	26	22	4	12	24	
2	26	22	4		24	
3	26	22	4		26	
4	26	22	4		25	
5	26	22	4		24	
6	26	22	4		23	
7	26	22	4		27	
8	28	24	4		23	
9	28	24	4		22	
10	28	24	4		24	
11	28	24	4		25	
12	28	24	4		26	
13	28	24	4		25	
14	28	24	4		26	
15	28	24	4		24	
16	28	24	4		24	
17	28	24	4		25	
18	28	24	4		25	
19	28	24	4		24	
20	28	24	4		24	
21	28	24	4		23	
22	28	24	4		22	
23	28	24	4		23	
24	28	24	4		24	
25	28	24	4		25	
26	28	24	4		24	
27	28	24	4		25	
28	28	24	4		23	
29	28	24	4		22	
30	28	24	4		23	
31	28	24	4		24	

<b>Cartridge Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes <input type="radio"/> No	CF's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/L?
	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No
Notes: PSI = pounds per square inch PSD = pounds per square inch difference (before filter - after filter) PSD When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSD.		PRINTED NAME: <u>Ludvik Wisniewski</u>	DATE: <u>4-1-26</u>
		SIGNATURE: <u>[Signature]</u>	
		PHONE #: <u>(503) 778-0302</u>	CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

**OHA - Drinking Water Program - Surface Water Quality Data Form**

System Name: Hawlet Quick Stop ID#: 94457 WTP: A Month/Year: Mar. '26

Date / Time	Minimum Chlorine Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	0.7	15	10.5			6		5 (Flowmeter)
2/	0.7		10.5					
3/	0.7		10.5					
4/	0.7		10.5					
5/	0.7		10.5		5.5			
6/	0.7		10.5					
7/	0.7		10.5					
8/	0.7		10.5					
9/	0.7		10.5					
10/	0.6		9		5.4			
11/	0.6		9					
12/	0.6		9					
13/	0.6		9					
14/	0.6		9					
15/	0.6		9					
16/	0.6		9		5.4			
17/	0.6		9					
18/	0.6		9					
19/	0.6		9					
20/	0.6		9					
21/	0.6		9					
22/	0.6		9		5.4			
23/	0.6		9					
24/	0.6		9					
25/	0.6		9					
26/	0.6		9					
27/	0.6		9					
28/	0.6		9		5.5			
29/	0.6		9					
30/	0.6		9					
31/	0.6		9					

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day. Revised February 2012