

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Cartridge or Bag Filtration

System Name: Hanlet Quick Stop ID # 94157 WTP: A Month/Year: May 22

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the Day (NTU)
1	26	22	4	12	.26	
2	26	22	4		.26	
3	26	22	4		.24	
4	26	22	4		.24	
5	26	22	4		.23	
6	26	22	4		.25	
7	26	22	4		.23	
8	26	22	4		.24	
9	26	22	4		.25	
10	26	22	4		.26	
11	26	22	4		.24	
12	28	24	4		.22	
13	28	24	4		.23	
14	28	24	4		.23	
15	28	24	4		.24	
16	28	24	4		.24	
17	28	24	4		.25	
18	28	24	4		.24	
19	28	24	4		.23	
20	28	24	4		.25	
21	28	24	4		.24	
22	28	24	4		.25	
23	28	24	4		.26	
24	28	24	4		.24	
25	28	24	4		.24	
26	28	24	4		.23	
27	28	24	4		.25	
28	28	24	4		.24	
29	28	24	4		.24	
30	28	24	4		.23	
31	28	24	4		.24	

**Cartridge Filtration**

95% of daily turbidity readings ≤ 1 NTU?  Yes  No  
 All daily turbidity readings ≤ 5 NTU?  Yes  No

CT's met everyday? (see back)  Yes  No

All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l?  Yes  No

Notes: PSI = pounds per square inch  
 PSID = pounds per square inch difference (before filter - after filter)  
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID

PRINTED NAME: Ludak Wisler

SIGNATURE: [Signature] DATE: \_\_\_\_\_

PHONE # 15031738-0302 CERT #: \_\_\_\_\_

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hawlet Duck Stop ID#: 4157 WTP: A Month/Year: May 12

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT Use tables	CT Met? <sup>2</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1/	0.6	15	9			6		5 (Flow restrictor)
2/	0.6		9					
3/	0.6		9		5.6			
4/	0.6		9					
5/	0.6		9					
6/	0.6		9					
7/	0.6		9					
8/	0.6		9					
9/	0.6		9					
10/	0.6		9		5.6			
11/	0.6		9					
12/	0.6		9					
13/	0.6		9					
14/	0.6		9					
15/	0.6		9					
16/	0.6		9					
17/	0.6		9		5.7			
18/	0.6		9					
19/	0.6		9					
20/	0.6		9					
21/	0.6		9					
22/	0.6		9					
23/	0.6		9					
24/	0.6		9		5.6			
25/	0.6		9					
26/	0.6		9					
27/	0.6		9					
28/	0.6		9					
29/	0.7		10.5					
30/	0.7		10.5		5.7			
31/	0.7	✓	10.5			✓		✓

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L OR CT not met, notify DWP by end of next business day. Revised February 2012