

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Walla Walla

Cartridge or Bag Filtration

Month/Year: 3-2021

System Name: Lake Shore Wtr & Dev Co ID#: OR 41 94169 WTP ID: TP-A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	10	6	4	35		93
2						89
3						91
4						73
5						81
6						67
7						84
8						72
9						70
10						62
11						87
12						61
13						55
14						73
15						84
16						81
17						96
18						77
19						62
20						47
21						65
22						89
23						46
24						63
25						67
26						83
27						49
28						57
29						36
30						59
31						

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU?

Yes /  No

All daily turbidity readings ≤ 5 NTU?

Yes /  No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes /  No

All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l?

Yes /  No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID

PRINTED NAME: MRS BURTON

SIGNATURE: [Signature] DATE: 4-1-2021

PHONE #: (509) 432-8106 CERT #:

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Lake Shore Wtr & Dev. <sup>CP</sup> ID# 41 024194169

Month/Year: 3-2021

Disinfection  
Giardia Log  
Inactiv: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	.4	1701	560	7	7.6	48	Y	10
2	.4	1400	560	7	7.5	48	Y	10
3	.4	1900	560	7	7.6	48	Y	10
4	.4	1400	560	7	7.3	48	Y	10
5	.4	1400	560	7	7.5	48	Y	10
6	.4	1400	560	7	7.6	48	Y	10
7	.4	1400	560	7	7.5	48	Y	10
8	.4	1400	560	7	7.1	48	Y	10
9	.4	1400	560	7	7.1	48	Y	10
10	.4	1400	560	7	7.4	48	Y	10
11	.4	1400	560	7	7.3	48	Y	10
12	.4	1400	560	7	7.2	48	Y	10
13	.4	1400	560	7	7.6	48	Y	10
14	.4	1400	560	7	7.5	48	Y	10
15	.4	1400	560	7	7.4	48	Y	10
16	.4	1400	560	7	7.3	48	Y	10
17	.4	1400	560	7	7.2	48	Y	10
18	.4	1400	560	7	7.6	48	Y	10
19	.4	1400	560	7	7.6	48	Y	10
20	.4	1400	560	7	7.3	48	Y	10
21	.4	1400	560	7	7.4	48	Y	10
22	.4	1400	560	7	7.8	48	Y	10
23	.4	1400	560	7	7.4	48	Y	10
24	.4	1400	560	7	7.6	48	Y	10
25	.4	1400	560	7	7.6	48	Y	10
26	.4	1400	560	7	7.6	48	Y	10
27	.4	1400	560	7	7.4	48	Y	10
28	.4	1400	560	7	7.5	48	Y	10
29	.4	1400	560	7	7.3	48	Y	10
30	.4	1400	560	7	7.2	48	Y	10
31	.4	1400	560	7	7.6	48	Y	10

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
dwp.dms@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350