

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Walla Walla

Cartridge or Bag Filtration

Month/Year: 2-2022

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the day ¹ (NTU)
1	0	0	0	25		37
2						34
3						81
4						72
5						56 56
6						60
7						49
8						38
9						74
10						91
11						38
12						55
13						72
14						87
15						38
16						59
17						85
18						66
19						58
20						75
21						99
22						78
23						44
24						57
25						1.09
26						46
27						51
28						69
29						43
30						48
31						94

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU? Yes / No

All daily turbidity readings ≤ 5 NTU? Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: J. KURON

SIGNATURE: J. KURON

DATE: 3-10-2022

PHONE #: (541) 432-8106

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: **A**

System Name: **Lake Shore Wtr & Dev. Corp. ID# 41 OR4194169** Month/Year: **2-2022**

Disinfection
Giardia Log
Inactiv: **1**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	5.5	1400	700	7	7.4	46	Y	10
2	4	1400	560	7	7.4	46	Y	10
3	4	1400	560	7	7.6	46	Y	10
4	4	1400	560	7	7.3	46	Y	10
5	5	1400	700	7	7.4	46	Y	10
6	4	1400	560	7	7.5	46	Y	10
7	4	1400	560	7	7.7	46	Y	10
8	4	1400	560	7	7.7	46	Y	10
9	4	1400	560	7	7.2	46	Y	10
10	4	1400	560	7	7.6	46	Y	10
11	4	1400	560	7	7.3	46	Y	10
12	4	1400	560	7	7.4	46	Y	10
13	4	1400	560	7	7.5	46	Y	10
14	5	1400	700	7	7.6	46	Y	10
15	5	1400	700	7	7.3	46	Y	10
16	5	1400	700	7	7.4	46	Y	10
17	5	1400	700	7	7.2	46	Y	10
18	5	1400	700	7	7.2	46	Y	10
19	5	1400	700	7	7.4	46	Y	10
20	5	1400	700	7	7.6	46	Y	10
21	5	1400	700	7	7.4	46	Y	10
22	5	1400	700	7	7.5	46	Y	10
23	5	1400	700	7	7.2	46	Y	10
24	5	1400	700	7	7.6	46	Y	10
25	5	1400	700	7	7.4	46	Y	10
26	5	1400	700	7	7.6	46	Y	10
27	5	1400	700	7	7.4	46	Y	10
28	5	1400	700	7	7.2	46	Y	10
29	5	1400	700	7	7.3	46	Y	10
30	5	1400	700	7	7.2	46	Y	10
31	15	1400	700	7	7.5	46	Y	10

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 dwp.dmca@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350