

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Walla Walla

Cartridge or Bag Filtration

Month/Year: 10-2022

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the day ¹ (NTU)
1	0	0	0	25		.23
2	0	0	0			.29
3	0	0	0			.38
4	0	0	0			.43
5	0	0	0			.55
6	0	0	0			.78
7	0	0	0			.45
8	1	1	1			.83
9	1	1	1			.69
10	1	1	1			.51
11	2	2	2			.49
12	2	2	2			.59
13	2	2	2			.72
14	2	2	2			.98
15	2	2	2			.84
16	2	2	2			.61
17	2	2	2			.89
18	2	2	2			.38
19	2	2	2			.56
20	2	2	2			.47
21	2	2	2			.52
22	2	2	2			.77
23	2	2	2			.58
24	2	2	2			.45
25	2	2	2			.39
26	2	2	2			.73
27	2	2	2			.88
28	2	2	2			.91
29	2	2	2			.72
30	2	2	2			.48
31	2	2	2			.83

<p>Cartridge & Bag Filtration</p> <p>95% of daily turbidity readings ≤ 1 NTU? <u>Yes/No</u></p> <p>All daily turbidity readings ≤ 5 NTU? <u>Yes/No</u></p>		<p>Monthly Summary (Answer Yes or No)</p> <p>CT's met everyday? (see back) <u>Yes/No</u></p> <p>All Cl2 residual at entry point ≥ 0.2 mg/l? <u>Yes/No</u></p>	
<p>Notes: PSI = pounds per square inch</p> <p>PSID = pounds per square inch difference (before filter - after filter)</p> <p>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID</p>		<p>PRINTED NAME: <u>Anna Becker</u></p> <p>SIGNATURE: <u>[Signature]</u></p> <p>PHONE #: <u>(541) 432-8106</u></p>	
		<p>DATE: <u>11-7-2022</u></p> <p>CERT #:</p>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

2022

WTP: A

System Name:

Lake Shore Wtr & Dev. Co.

ID#: 41

024194169

Month/Year:

10-2022

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	.5	1400	700	8	7.4	46	Y	10
2	.5	1400	700	8	7.4	46	Y	10
3	.5	1400	700	8	7.6	46	Y	10
4	.4	1400	560	8	7.3	46	Y	10
5	.4	1400	560	8	7.4	46	Y	10
6	.4	1400	560	8	7.6	46	Y	10
7	.4	1400	560	8	7.5	46	Y	10
8	.4	1400	560	8	7.3	46	Y	10
9	.4	1400	560	8	7.2	46	Y	10
10	.5	1400	700	8	7.7	46	Y	10
11	.5	1400	700	8	7.5	46	Y	10
12	.5	1400	700	8	7.6	46	Y	10
13	.5	1400	700	8	7.6	46	Y	10
14	.5	1400	700	8	7.4	46	Y	10
15	.4	1400	560	8	7.5	46	Y	10
16	.5	1400	700	8	7.3	46	Y	10
17	.5	1400	700	8	7.3	46	Y	10
18	.5	1400	700	8	7.4	46	Y	10
19	.5	1400	700	8	7.4	46	Y	10
20	.5	1400	700	8	7.4	46	Y	10
21	.5	1400	700	8	7.3	46	Y	10
22	.4	1400	560	8	7.1	46	Y	10
23	.4	1400	560	8	7.5	46	Y	10
24	.4	1400	560	8	7.4	46	Y	10
25	.4	1400	560	8	7.6	46	Y	10
26	.4	1400	560	8	7.4	46	Y	10
27	.4	1400	560	8	7.5	46	Y	10
28	.4	1400	560	8	7.2	46	Y	10
29	.4	1400	560	8	7.2	46	Y	10
30	.4	1400	560	8	7.4	46	Y	10
31	.4	1400	560	8	7.5	46	Y	10

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmc@state.or.us; 971-873-0894; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised July 2018