

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Walla Walla

Cartridge or Bag Filtration

Month/Year: 12 2022

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1				28		91
2						89
3						73
4						67
5						37
6						78
7						64
8						83
9						47
10						55
11						69
12						62
13						1.08
14						94
15						1.03
16						71
17						62
18						93
19						74
20						39
21						37
22						62
23						95
24						63
25						91
26						72
27						94
28						43
29						82
30						37
31						

Cartridge & Bag Filtration

95% of daily turbidity readings \leq 1 NTU? Yes / No

All daily turbidity readings \leq 5 NTU? Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point \geq 0.2 mg/l? Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: James Barrett

SIGNATURE: [Signature] DATE: 1-10-2023

PHONE #: (541) 432-8106 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

Disinfection
Giardia Log
Inactiv: 1

System Name: Lake Shore Wtr & Dev. ^{Corp} ID#: 41 024194169

Month/Year: 12 2022

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [°C]	pH	Required CT formula	CT Met? ² Yes / No	Peak Hourly Demand Flow
								[GPM] ¹
1	.4	1400	560	7	6.9	46	Y	10
2	.4	1400	560	7	7.2	46	Y	10
3	.4	1400	560	7	7.0	46	Y	10
4	.4	1400	560	7	7.1	46	Y	10
5	.4	1400	560	7	7.2	46	Y	10
6	.4	1400	560	7	6.9	46	Y	10
7	.4	1400	560	7	7.3	46	Y	10
8	.4	1400	560	7	7.4	46	Y	10
9	.4	1400	560	7	7.0	46	Y	10
10	.4	1400	560	7	7.1	46	Y	10
11	.4	1400	560	7	7.1	46	Y	10
12	.4	1400	560	7	7.3	46	Y	10
13	.4	1400	560	7	7.0	46	Y	10
14	.4	1400	560	7	6.8	46	Y	10
15	.4	1400	560	7	7.2	46	Y	10
16	.4	1400	560	7	7.3	46	Y	10
17	.4	1400	560	7	7.1	46	Y	10
18	.4	1400	560	7	7.1	46	Y	10
19	.4	1400	560	7	7.1	46	Y	10
20	.4	1400	560	7	6.9	46	Y	10
21	.4	1400	560	7	7.0	46	Y	10
22	.4	1400	560	7	7.3	46	Y	10
23	.4	1400	560	7	7.2	46	Y	10
24	.4	1400	560	7	7.3	46	Y	10
25	.4	1400	560	7	7.0	46	Y	10
26	.4	1400	560	7	7.2	46	Y	10
27	.4	1400	560	7	6.9	46	Y	10
28	.4	1400	560	7	7.3	46	Y	10
29	.4	1400	560	7	7.1	46	Y	10
30	.4	1400	560	7	7.0	46	Y	10
31								

Revised July 2018

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-873-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350