

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Wallawa

Cartridge or Bag Filtration

Month/Year: 12 2025

| Day | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day <sup>1</sup> [NTU] |
|-----|-------------------|------------------|------|----------------------------|-------------------------------|---|
| 1   |                   |                  |      | 25                         |                               | .49   |
| 2   |                   |                  |      |                            |                               | .44   |
| 3   |                   |                  |      |                            |                               | .67   |
| 4   |                   |                  |      |                            |                               | .38   |
| 5   |                   |                  |      |                            |                               | .72   |
| 6   |                   |                  |      |                            |                               | .91   |
| 7   |                   |                  |      |                            |                               | .48   |
| 8   |                   |                  |      |                            |                               | .64   |
| 9   |                   |                  |      |                            |                               | .47   |
| 10  |                   |                  |      |                            |                               | .30   |
| 11  |                   |                  |      |                            |                               | .99   |
| 12  |                   |                  |      |                            |                               | .85   |
| 13  |                   |                  |      |                            |                               | .51   |
| 14  |                   |                  |      |                            |                               | .84   |
| 15  |                   |                  |      |                            |                               | .37   |
| 16  |                   |                  |      |                            |                               | .48   |
| 17  |                   |                  |      |                            |                               | .73   |
| 18  |                   |                  |      |                            |                               | .79   |
| 19  |                   |                  |      |                            |                               | .78   |
| 20  |                   |                  |      |                            |                               | 1.08  |
| 21  |                   |                  |      |                            |                               | .42   |
| 22  |                   |                  |      |                            |                               | .63   |
| 23  |                   |                  |      |                            |                               | .75   |
| 24  |                   |                  |      |                            |                               | .69   |
| 25  |                   |                  |      |                            |                               | .72   |
| 26  |                   |                  |      |                            |                               | .42   |
| 27  |                   |                  |      |                            |                               | .85   |
| 28  |                   |                  |      |                            |                               | .33   |
| 29  |                   |                  |      |                            |                               | .71   |
| 30  |                   |                  |      |                            |                               | .52   |
| 31  |                   |                  |      |                            |                               | .37   |

|   |          |   |   |
|---|----------|---|---|
| <b>Cartridge &amp; Bag Filtration</b>   |          | <b>Monthly Summary (Answer Yes or No)</b> |   |
| 95% of daily turbidity readings ≤ 1 NTU?  | Yes / No | CT's met everyday? (see back)             | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU?   | Yes / No | Yes / No                                  | Yes / No                                    |
| Notes: PSI = pounds per square inch<br>PSID = pounds per square inch difference (before filter - after filter)<br>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID |          | PRINTED NAME: <u>AMMO BURTON</u>          | DATE: <u>1-8-20 2021</u>                    |
|   |          | SIGNATURE: <u>[Signature]</u>             | CERT #:                                     |
|   |          | PHONE #: <u>(541) 432-8106</u>            |   |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: **A**

System Name: **Lake Shore Wtr & Dev.** ID#: **41 024194169** Month/Year: **12 2023**  
 Disinfection **Giardia Log Inactiv:** **1**

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup> | Contact Time (T) | Actual CT | Temp  | pH  | Required CT | CT Met? <sup>2</sup> | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|-------|-----|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]   | [minutes]        | C X T     | [° C] |     | formula     | Yes / No             | [GPM]                   |
| 1           | .4  | 1400             | 560       | 7     | 7.4 | 46          | Y                    | 10                      |
| 2           | .4  | 1400             | 560       | 7     | 7.2 | 46          | Y                    | 10                      |
| 3           | .4  | 1400             | 560       | 7     | 7.2 | 46          | Y                    | 10                      |
| 4           | .4  | 1400             | 560       | 7     | 7.6 | 46          | Y                    | 10                      |
| 5           | .4  | 1400             | 560       | 7     | 7.5 | 46          | Y                    | 10                      |
| 6           | .4  | 1400             | 560       | 7     | 7.6 | 46          | Y                    | 10                      |
| 7           | .4  | 1400             | 560       | 7     | 7.2 | 46          | Y                    | 10                      |
| 8           | .4  | 1400             | 560       | 7     | 7.3 | 46          | Y                    | 10                      |
| 9           | .4  | 1400             | 560       | 7     | 7.2 | 46          | Y                    | 10                      |
| 10          | .4  | 1400             | 560       | 7     | 7.4 | 46          | Y                    | 10                      |
| 11          | .4  | 1400             | 560       | 7     | 7.3 | 46          | Y                    | 10                      |
| 12          | .4  | 1400             | 560       | 7     | 7.2 | 46          | Y                    | 10                      |
| 13          | .4  | 1400             | 560       | 7     | 7.5 | 46          | Y                    | 10                      |
| 14          | .4  | 1400             | 560       | 7     | 7.3 | 46          | Y                    | 10                      |
| 15          | .4  | 1400             | 560       | 7     | 7.4 | 46          | Y                    | 10                      |
| 16          | .4  | 1400             | 560       | 7     | 7.6 | 46          | Y                    | 10                      |
| 17          | .4  | 1400             | 560       | 7     | 7.3 | 46          | Y                    | 10                      |
| 18          | .4  | 1400             | 560       | 7     | 7.5 | 46          | Y                    | 10                      |
| 19          | .4  | 1400             | 560       | 7     | 7.6 | 46          | Y                    | 10                      |
| 20          | .4  | 1400             | 560       | 7     | 7.6 | 46          | Y                    | 10                      |
| 21          | .4  | 1400             | 560       | 7     | 7.2 | 46          | Y                    | 10                      |
| 22          | .4  | 1400             | 560       | 7     | 7.4 | 46          | Y                    | 10                      |
| 23          | .4  | 1400             | 560       | 7     | 7.3 | 46          | Y                    | 10                      |
| 24          | .4  | 1400             | 560       | 7     | 7.6 | 46          | Y                    | 10                      |
| 25          | .4  | 1400             | 560       | 7     | 7.2 | 46          | Y                    | 10                      |
| 26          | .4  | 1400             | 560       | 7     | 7.4 | 46          | Y                    | 10                      |
| 27          | .4  | 1400             | 560       | 7     | 7.3 | 46          | Y                    | 10                      |
| 28          | .4  | 1400             | 560       | 7     | 7.6 | 46          | Y                    | 10                      |
| 29          | .4  | 1400             | 560       | 7     | 7.3 | 46          | Y                    | 10                      |
| 30          | .4  | 1400             | 560       | 7     | 7.4 | 46          | Y                    | 10                      |
| 31          | .4  | 1400             | 560       | 7     | 7.2 | 46          | Y                    | 10                      |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours. Return by 10th of following month by email, fax, or mail to: [dwp.dnce@state.or.us](mailto:dwp.dnce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised July 2018