

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Walla Walla

Cartridge or Bag Filtration

Month/Year: _____

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	0	0	0	25		84
2		0				51
3		0				91
4		10	10			87
5		10	10			49
6		10	10			58
7		10	10			55
8		10	10			69
9		10	10			81
10		10	10			38
11		12	12			72
12		12	12			60
13		12	12			58
14		12	12			83
15		12	12			52
16		12	12			48
17		13	13			41
18		13	13			92
19		13	13			98
20		13	13			87
21		14	14			83
22		14	14			71
23		14	14			78
24		14	14			88
25		14	14			72
26		14	14			57
27		14	14			63
28		15	15			82
29		15	15			51
30		15	15			42
31						

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes/No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes/No	Yes/No	Yes/No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.		PRINTED NAME: <u>Anna Burro</u>	DATE: <u>6-9-2024</u>
		SIGNATURE: <u>[Signature]</u>	CERT #:
		PHONE #: <u>(541) 432-8106</u>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: **A**

System Name: **Lake Shore Wtr & Dev.** ID#: **41 024194169**

Month/Year:

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	.5	1400	700	8	7.4	46	Y	10
2	.5	1400	700	8	7.4	46	Y	10
3	.5	933	466	8	7.6	46	Y	15
4	.5	933	466	8	7.2	46	Y	15
5	.5	933	466	8	7.4	46	Y	15
6	.5	933	466	8	7.3	46	Y	15
7	.5	700	350	8	7.1	45	Y	20
8	.5	700	350	8	7.5	46	Y	20
9	.5	933	466	8	7.4	46	Y	15
10	.5	933	466	8	7.6	46	Y	15
11	.5	700	350	8	7.6	46	Y	20
12	.5	700	350	8	7.5	46	Y	20
13	.5	560	280	8	7.5	46	Y	25
14	.5	560	280	8	7.4	46	Y	25
15	.5	467	233	8	7.2	46	Y	30
16	.5	560	280	8	7.2	46	Y	25
17	.5	700	350	8	7.4	46	Y	20
18	.5	467	233	8	7.5	46	Y	30
19	.5	467	233	8	7.4	46	Y	30
20	.6	560	336	8	7.6	46	Y	25
21	.6	560	336	8	7.5	48	Y	25
22	.6	467	280	8	7.4	48	Y	30
23	.6	467	280	8	7.5	48	Y	30
24	.6	560	336	8	7.2	48	Y	25
25	.6	467	280	8	7.3	48	Y	30
26	.6	467	280	8	7.6	48	Y	30
27	.6	467	280	8	7.1	48	Y	30
28	.6	467	280	8	7.3	48	Y	30
29	.6	467	280	8	7.2	48	Y	30
30	.6	467	280	8	7.3	48	Y	30
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350