

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Wallawa

Cartridge or Bag Filtration

Month/Year: 3-2025

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	0	0	0	25		43
2						38
3						64
4						47
5						38
6						91
7						82
8						71
9						79
10						45
11						55
12						64
13						38
14						72
15						51
16						84
17						33
18						27
19						52
20						63
21						48
22						77
23						69
24						39
25						85
26						31
27						48
28						63
29						41
30						33
31						91

Cartridge & Bag Filtration

95% of daily turbidity readings $\leq$ 1 NTU?

Yes / No

All daily turbidity readings $\leq$ 5 NTU?

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point $\geq$ 0.2 mg/l?

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: AMES BURTONSIGNATURE: [Signature]DATE: 4-9-2025PHONE #: (541) 432-8106

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: **A**System Name: **Lake Shore Wtr & Dev. Co.** ID# 41 **024194169**Month/Year: **3-2025**Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	.4	1400	560	7	7.4	46 X 46	Y	10
2	.4	1400	560	7	7.4	46 X 46	Y	10
3	.4	1400	560	7	7.6	46 X 46	Y	10
4	.4	1400	560	7	7.4	46 X 46	Y	10
5	.4	1400	560	8	7.3	46 X 46	Y	10
6	.4	1400	560	8	7.6	46 X 46	Y	10
7	.4	1400	560	8	7.5	46 X 46	Y	10
8	.4	1400	560	8	7.4	46 X 46	Y	10
9	.4	1400	560	8	7.6	46 X 46	Y	10
10	.4	1400	560	7	7.2	46 X 46	Y	10
11	.4	1400	560	7	7.4	46 X 46	Y	10
12	.4	1400	560	7	7.5	46 X 46	Y	10
13	.4	1400	560	7	7.5	46 X 46	Y	10
14	.4	1400	560	7	7.4	46 X 46	Y	10
15	.4	1400	560	8	7.3	46 X 46	Y	10
16	.4	1400	560	8	7.6	46 X 46	Y	10
17	.4	1400	560	8	7.6	46 X 46	Y	10
18	.4	1400	560	8	7.6	46 X 46	Y	10
19	.4	1400	560	8	7.4	46 X 46	Y	10
20	.4	1400	560	8	7.3	46 X 46	Y	10
21	.7	1400	560	8	7.4	46 X 46	Y	10
22	.4	1400	560	8	7.6	46 X 46	Y	10
23	.4	1400	560	8	7.6	46 X 46	Y	10
24	.4	1400	560	8	7.4	46 X 46	Y	10
25	.4	1400	560	8	7.6	46 X 46	Y	10
26	.4	1400	560	8	7.5	46 X 46	Y	10
27	.7	1400	560	8	7.3	46 X 46	Y	10
28	.4	1400	560	8	7.4	46 X 46	Y	10
29	.4	1400	560	8	7.6	46 X 46	Y	10
30	.4	1400	560	8	7.4	46 X 46	Y	10
31	.4	1400	560	8	7.3	46 X 46	Y	10

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350