

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Wallawa

Cartridge or Bag Filtration

Month/Year: 5 2025

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1				25		81
2						32
3						57
4						48
5						38
6						55
7						91
8						47
9						83
10						55
11						69
12						40
13						43
14						32
15						88
16						74
17						81
18						37
19						82
20						66
21						68
22						52
23						47
24						33
25						59
26						72
27						63
28						83
29						35
30						53
31						62

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU?

Yes / No

All daily turbidity readings ≤ 5 NTU?

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l?

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: AMAS BORTONSIGNATURE: [Signature]

DATE:

PHONE #: (541) 432-8106

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Lake Shore Wtr & Dev. ID# 41 024194169

Month/Year: 5 2025

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	.5	1400	700	8	7.2	46	Y	10
2	.5	1400	700	8	7.3	46	Y	10
3	.5	1400	700	8	7.3	46	Y	10
4	.5	1400	700	8	7.3	46	Y	10
5	.5	1400	700	8	7.4	46	Y	10
6	.5	1400	700	8	7.3	46	Y	10
7	.5	1400	700	8	7.2	46	Y	10
8	.5	1400	700	8	7.6	46	Y	10
9	.5	1400	700	8	7.7	46	Y	10
10	.5	933	466	8	7.4	46	Y	15
11	.5	1400	700	8	7.2	46	Y	10
12	.5	933	466	8	7.4	46	Y	15
13	.5	1400	700	8	7.2	46	Y	10
14	.5	1400	700	8	7.3	46	Y	10
15	.5	933	466	8	7.4	46	Y	15
16	.5	933	466	8	7.5	46	Y	15
17	.5	1400	700	8	7.5	46	Y	10
18	.5	933	466	8	7.4	46	Y	15
19	.5	933	466	8	7.2	46	Y	15
20	.5	700	350	8	7.3	46	Y	20
21	.5	700	350	8	7.3	46	Y	20
22	.5	700	350	8	7.3	46	Y	20
23	.5	700	350	8	7.4	46	Y	20
24	.5	700	350	8	7.4	46	Y	20
25	.5	500	280	8	7.2	46	Y	25
26	.5	700	280	8	7.3	46	Y	20
27	.5	933	466	8	7.4	46	Y	15
28	.5	933	466	8	7.3	46	Y	15
29	.5	933	466	8	7.3	46	Y	15
30	.5	933	466	8	7.4	46	Y	15
31	.5	933	466	8	7.4	46	Y	15

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350