

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Wallawa

Cartridge or Bag Filtration

Month/Year: 7-2025

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	0	0	0	25		.93
2						1.04
3						.46
4						.97
5						.72
6						.43
7						.89
8						1.09
9						.72
10						.68
11						.91
12						.88
13						.63
14						.75
15						.67
16						.84
17						.87
18						.93
19						.47
20						.82
21						1.14
22						.89
23						.93
24						.55
25						.68
26						.47
27						.59
28						.65
29						.48
30						.91
31						.70

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU?

Yes / No

All daily turbidity readings ≤ 5 NTU?

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l?

Yes / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: JAMES BOSTONSIGNATURE: [Signature]DATE: 7-7-2025PHONE #: (541) 432-8106

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: A

System Name:

Lake Shore Wtr & Dev.

ID#: 41
034194169

Month/Year:

7-2025

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	.6	311	186	8	7.4	48	Y	45
2	.6	280	168	8	7.4	49	Y	30
3	.6	200	120	8	7.6	48	Y	70
4	.6	215	129	8	7.1	48	Y	65
5	.6	200	120	8	7.6	48	Y	70
6	.5	215	107	8	7.5	46	Y	65
7	.5	233	116	8	7.4	46	Y	60
8	.5	233	116	8	7.4	46	Y	60
9	.6	233	139	8	7.6	48	Y	60
10	.6	200	120	8	7.5	48	Y	70
11	.6	233	139	8	7.6	48	Y	60
12	.5	255	127	8	7.6	46	Y	55
13	.5	255	127	8	7.5	46	Y	55
14	.5	233	116	8	7.5	46	Y	60
15	.5	233	116	8	7.6	46	Y	60
16	.5	200	100	8	7.1	46	Y	70
17	.5	215	107	8	7.2	46	Y	65
18	.6	200	120	8	7.2	48	Y	70
19	.6	200	120	8	7.4	48	Y	70
20	.6	215	129	8	7.2	48	Y	65
21	.6	233	139	8	7.6	48	Y	60
22	.6	233	139	8	7.4	48	Y	60
23	.6	233	139	8	7.6	48	Y	60
24	.6	215	129	8	7.5	46	Y	65
25	.6	233	139	8	7.4	48	Y	60
26	.6	200	120	8	7.5	48	Y	70
27	.6	233	139	8	7.6	48	Y	60
28	.6	233	139	8	7.3	48	Y	60
29	.6	200	120	8	7.5	48	Y	70
30	.6	200	120	8	7.6	48	Y	70
31	.6	200	120	8	7.6	48	Y	70

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised July 2018