


OHA - Drinking Water Program - Surface Water Quality Data Form					County:	Lane
Cartridge or Bag Filtration					Month/Year:	March 2021
System Name:	Woahink Lake Suites			ID#: 4194188	WTP ID: WTP-A	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1			28.00		0.15	
2			30.00		0.14	
3			32.00		0.23	
4			24.00		0.17	
5			26.00		0.20	
6			27.00		0.17	
7			0.00		0.22	
8			0.00		0.22	
9			0.00		0.15	
10			1.00		0.17	
11			1.00		0.15	
12			2.00		0.18	
13			2.00		0.12	
14			2.00		0.12	
15			2.00		0.21	
16			3.00		0.14	
17			3.00		0.16	
18			3.00		0.13	
19			3.00		0.21	
20			3.00		0.26	
21			3.00		0.18	
22			4.00		0.23	
23			4.00		0.16	
24			4.00		0.11	
25			4.00		0.18	
26			4.00		0.14	
27			4.00		0.20	
28			4.00		0.15	
29			4.00		0.26	
30			4.00		0.30	
31			5.00		0.21	
Cartridge & Bag Filtration				Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				Yes	Yes	Yes
Notes: PSI = pounds per square inch				PRINTED NAME: Dan Reitz		
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE: 		DATE: 04/09/2021
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				PHONE #: (541) 342-1718		CERT #: D&T 6528

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - A	
System Name:	Woahink Lake Suites		ID#: 4194188		Month/Year:	March 2021	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.26	100	126.0	10.8	6.5	31.9	Yes	
2	1.61	100	161.0	10.6	6.6	34.4	Yes	
3	2.00	100	200.0	11.1	6.4	33.0	Yes	
4	2.00	100	200.0	10.9	6.6	35.2	Yes	
5	2.00	100	200.0	11.3	6.4	32.8	Yes	
6	0.50	100	50.0	11.6	6.7	29.5	Yes	
7	1.45	100	145.0	11.0	6.4	31.1	Yes	
8	1.52	100	152.0	11.5	6.4	30.5	Yes	
9	1.29	100	129.0	11.1	6.5	30.9	Yes	
10	1.01	100	101.0	11.2	6.7	32.0	Yes	
11	0.97	100	97.0	11.8	6.5	29.1	Yes	
12	1.10	100	110.0	11.7	6.8	32.1	Yes	
13	0.86	100	86.0	13.7	6.3	22.7	Yes	
14	0.93	100	93.0	11.3	6.7	32.1	Yes	
15	0.63	100	63.0	12.1	6.8	29.9	Yes	
16	0.89	100	89.0	11.7	5.8	22.6	Yes	
17	0.71	100	71.0	12.5	5.8	19.8	Yes	
18	0.50	100	50.0	12.2	6.6	27.9	Yes	
19	0.53	100	53.0	12.3	6.8	29.5	Yes	
20	0.61	100	61.0	12.6	6.7	27.8	Yes	
21	0.80	100	80.0	12.0	6.6	29.0	Yes	
22	0.89	100	89.0	11.6	6.9	33.2	Yes	
23	1.05	100	105.0	11.9	7.0	34.4	Yes	
24	1.01	100	101.0	12.4	6.9	31.7	Yes	
25	0.89	100	89.0	13.1	6.8	28.4	Yes	
26	0.93	100	93.0	12.7	6.9	29.8	Yes	
27	1.03	100	103.0	12.8	6.7	27.7	Yes	
28	1.20	100	120.0	13.4	6.6	26.7	Yes	
29	1.28	100	128.0	13.4	6.5	26.2	Yes	
30	1.21	100	121.0	12.8	6.8	29.5	Yes	
31	0.92	100	92.0	13.3	6.7	27.1	Yes	
2 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.							Revised February 2012	
PAGE 2 of 2								