


| OHA - Drinking Water Program - Surface Water Quality Data Form   |                     |                  |      |   | County:                       | Lane  |
|--|---------------------|------------------|------|---|-------------------------------|---|
| Cartridge or Bag Filtration  |                     |                  |      |   | Month/Year:                   | August 2021                                 |
| System Name:   | Woahink Lake Suites |                  |      | ID#: 4194188  | WTP ID: WTP-A                 |   |
| Day  | PSI Before Filter   | PSI After Filter | PSID | PSID When to Change Filter  | Daily Turbidity Reading [NTU] | Highest Reading of the day 1 [NTU]          |
| 1  |                     |                  | 8.00 |   | 0.28                          |   |
| 2  |                     |                  | 8.00 |   | 0.30                          |   |
| 3  |                     |                  | 8.00 |   | 0.42                          |   |
| 4  |                     |                  | 8.00 |   | 0.39                          |   |
| 5  |                     |                  | 8.00 |   | 0.40                          |   |
| 6  |                     |                  | 8.00 |   | 0.47                          |   |
| 7  |                     |                  | 8.00 |   | 0.49                          |   |
| 8  |                     |                  | 8.00 |   | 0.48                          |   |
| 9  |                     |                  | 9.00 |   | 0.44                          |   |
| 10   |                     |                  | 9.00 |   | 0.40                          |   |
| 11   |                     |                  | 9.00 |   | 0.38                          |   |
| 12   |                     |                  | 9.00 |   | 0.39                          |   |
| 13   |                     |                  | 9.00 |   | 0.41                          |   |
| 14   |                     |                  | 9.00 |   | 0.46                          |   |
| 15   |                     |                  | 9.00 |   | 0.44                          |   |
| 16   |                     |                  | 9.00 |   | 0.42                          |   |
| 17   |                     |                  | 9.00 |   | 0.50                          |   |
| 18   |                     |                  | 9.00 |   | 0.65                          |   |
| 19   |                     |                  | 9.00 |   | 0.79                          |   |
| 20   |                     |                  | 9.00 |   | 0.60                          |   |
| 21   |                     |                  | 9.00 |   | 0.46                          |   |
| 22   |                     |                  | 9.00 |   | 0.48                          |   |
| 23   |                     |                  | 9.00 |   | 0.62                          |   |
| 24   |                     |                  | 9.00 |   | 0.30                          |   |
| 25   |                     |                  | 9.00 |   | 0.32                          |   |
| 26   |                     |                  | 9.00 |   | 0.37                          |   |
| 27   |                     |                  | 9.00 |   | 0.24                          |   |
| 28   |                     |                  | 9.00 |   | 0.41                          |   |
| 29   |                     |                  | 9.00 |   | 0.48                          |   |
| 30   |                     |                  | 9.00 |   | 0.36                          |   |
| 31   |                     |                  | 9.00 |   | 0.34                          |   |
| Cartridge & Bag Filtration   |                     |                  |      | Monthly Summary (Answer Yes or No)  |                               |   |
| 95% of daily turbidity readings ≤ 1 NTU?   |                     |                  |      | Yes   | CT's met everyday? (see back) | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU?  |                     |                  |      | Yes   | Yes                           | Yes   |
| Notes: PSI = pounds per square inch  |                     |                  |      | PRINTED NAME: Dan Reitz   |                               |   |
| PSID = pounds per square inch difference (before filter - after filter)  |                     |                  |      | SIGNATURE:  |                               | DATE: 09/09/2021                            |
| PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID. |                     |                  |      | PHONE #: ( 541 ) 342-1718   |                               | CERT #: D&T 6528                            |

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

| OHA - Drinking Water Program - Surface Water Quality Data Form                                    |  |                  |              |       |             |             | WTP - A                           |                         |
|---|--|------------------|--------------|-------|-------------|-------------|-----------------------------------|-------------------------|
| System Name:  | Woahink Lake Suites                      |                  | ID#: 4194188 |       | Month/Year: | August 2021 | Disinfection Giardia Log Inactiv: | 1                       |
| Date / Time   | Minimum Cl2 Residual at 1st User ( C ) 2 | Contact Time (T) | Actual CT    | Temp  | pH          | Required CT | CT Met? 2                         | Peak Hourly Demand Flow |
|   | [ppm or mg/L]                            | [minutes]        | <b>C X T</b> | [° C] |             | formula     | Yes / No                          | [GPM]                   |
| 1   | 1.20                                     | 100              | 120.0        | 18.9  | 6.2         | 15.9        | Yes                               |                         |
| 2   | 1.40                                     | 100              | 140.0        | 19.3  | 6.0         | 14.8        | Yes                               |                         |
| 3   | 1.25                                     | 100              | 125.0        | 20.9  | 6.0         | 12.6        | Yes                               |                         |
| 4   | 1.36                                     | 100              | 136.0        | 21.2  | 6.1         | 13.5        | Yes                               |                         |
| 5   | 1.35                                     | 100              | 135.0        | 20.4  | 5.8         | 12.4        | Yes                               |                         |
| 6   | 1.39                                     | 100              | 138.5        | 20.6  | 6.2         | 14.2        | Yes                               |                         |
| 7   | 1.40                                     | 100              | 140.0        | 20.3  | 6.0         | 13.9        | Yes                               |                         |
| 8   | 1.24                                     | 100              | 124.0        | 21.3  | 6.0         | 12.6        | Yes                               |                         |
| 9   | 1.11                                     | 100              | 111.0        | 21.1  | 5.6         | 10.7        | Yes                               |                         |
| 10  | 1.20                                     | 100              | 120.0        | 21.4  | 6.0         | 12.3        | Yes                               |                         |
| 11  | 1.12                                     | 100              | 112.0        | 20.6  | 5.9         | 12.5        | Yes                               |                         |
| 12  | 1.18                                     | 100              | 118.0        | 21.1  | 6.0         | 12.6        | Yes                               |                         |
| 13  | 1.13                                     | 100              | 113.0        | 20.6  | 5.9         | 12.5        | Yes                               |                         |
| 14  | 1.15                                     | 100              | 115.0        | 20.4  | 6.0         | 13.1        | Yes                               |                         |
| 15  | 1.17                                     | 100              | 117.0        | 19.9  | 5.8         | 12.8        | Yes                               |                         |
| 16  | 1.16                                     | 100              | 116.0        | 19.8  | 5.8         | 12.9        | Yes                               |                         |
| 17  | 1.00                                     | 100              | 100.0        | 20.2  | 5.4         | 10.3        | Yes                               |                         |
| 18  | 1.04                                     | 100              | 104.0        | 20.1  | 5.6         | 11.4        | Yes                               |                         |
| 19  | 1.09                                     | 100              | 109.0        | 20.1  | 5.8         | 12.4        | Yes                               |                         |
| 20  | 1.08                                     | 100              | 108.0        | 19.4  | 5.4         | 11.1        | Yes                               |                         |
| 21  | 1.12                                     | 100              | 112.0        | 19.5  | 5.7         | 12.3        | Yes                               |                         |
| 22  | 1.60                                     | 100              | 160.0        | 18.9  | 5.6         | 13.2        | Yes                               |                         |
| 23  | 0.96                                     | 100              | 96.0         | 18.9  | 5.7         | 12.8        | Yes                               |                         |
| 24  | 0.89                                     | 100              | 89.0         | 19.2  | 5.5         | 11.4        | Yes                               |                         |
| 25  | 0.90                                     | 100              | 90.0         | 19.1  | 5.6         | 12.0        | Yes                               |                         |
| 26  | 0.95                                     | 100              | 95.0         | 20.3  | 5.8         | 11.8        | Yes                               |                         |
| 27  | 1.00                                     | 100              | 100.0        | 19.4  | 5.8         | 12.8        | Yes                               |                         |
| 28  | 0.93                                     | 100              | 93.0         | 18.9  | 5.9         | 13.7        | Yes                               |                         |
| 29  | 0.90                                     | 100              | 90.0         | 19.1  | 6.0         | 13.8        | Yes                               |                         |
| 30  | 0.98                                     | 100              | 98.0         | 19.1  | 5.9         | 13.5        | Yes                               |                         |
| 31  | 1.00                                     | 100              | 100.0        | 19.2  | 6.0         | 13.9        | Yes                               |                         |
| 2 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day. |  |                  |              |       |             |             | Revised February 2012             |                         |
| PAGE 2 of 2   |  |                  |              |       |             |             |                                   |                         |