


| OHA - Drinking Water Program - Surface Water Quality Data Form | | | | | County: | Lane |
|--|---------------------|------------------|-------|---|-------------------------------|---|
| Cartridge or Bag Filtration | | | | | Month/Year: | April 2022 |
| System Name: | Woahink Lake Suites | | | ID#: 4194188 | WTP ID: WTP-A | |
| Day | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day 1 [NTU] |
| 1 | | | 7.00 | | 0.29 | |
| 2 | | | 7.00 | | 0.29 | |
| 3 | | | 7.00 | | 0.30 | |
| 4 | | | 7.00 | | 0.32 | |
| 5 | | | 7.00 | | 0.31 | |
| 6 | | | 8.00 | | 0.50 | |
| 7 | | | 8.00 | | 0.43 | |
| 8 | | | 8.00 | | 0.28 | |
| 9 | | | 8.00 | | 0.48 | |
| 10 | | | 8.00 | | 0.50 | |
| 11 | | | 9.00 | | 0.42 | |
| 12 | | | 9.00 | | 0.36 | |
| 13 | | | 9.00 | | 0.52 | |
| 14 | | | 9.00 | | 0.25 | |
| 15 | | | 9.00 | | 0.58 | |
| 16 | | | 9.00 | | 0.28 | |
| 17 | | | 9.00 | | 0.29 | |
| 18 | | | 10.00 | | 0.30 | |
| 19 | | | 10.00 | | 0.25 | |
| 20 | | | 10.00 | | 0.37 | |
| 21 | | | 10.00 | | 0.29 | |
| 22 | | | 11.00 | | 0.28 | |
| 23 | | | 11.00 | | 0.20 | |
| 24 | | | 11.00 | | 0.39 | |
| 25 | | | 11.00 | | 0.37 | |
| 26 | | | 12.00 | | 0.42 | |
| 27 | | | 12.00 | | 0.45 | |
| 28 | | | 13.00 | | 0.50 | |
| 29 | | | 14.00 | | 0.57 | |
| 30 | | | 14.00 | | 0.60 | |
| 31 | | | | | | |
| Cartridge & Bag Filtration | | | | Monthly Summary (Answer Yes or No) | | |
| 95% of daily turbidity readings ≤ 1 NTU? | | | | Yes | CT's met everyday? (see back) | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU? | | | | Yes | Yes | Yes |
| Notes: PSI = pounds per square inch | | | | PRINTED NAME: Dan Reitz | | |
| PSID = pounds per square inch difference (before filter - after filter) | | | | SIGNATURE:  | | DATE: 05/09/2022 |
| PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID. | | | | PHONE #: (541) 342-1718 | | CERT #: D&T 6528 |

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

| OHA - Drinking Water Program - Surface Water Quality Data Form | | | | | | | WTP - A | |
|---|--|------------------|--------------|-------|-------------|-------------|-----------------------------------|-------------------------|
| System Name: | Woahink Lake Suites | | ID#: 4194188 | | Month/Year: | April 2022 | Disinfection Giardia Log Inactiv: | 1 |
| Date / Time | Minimum Cl2 Residual at 1st User (C) 2 | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? 2 | Peak Hourly Demand Flow |
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 0.86 | 100 | 86.0 | 13.6 | 5.5 | 16.9 | Yes | |
| 2 | 0.99 | 100 | 99.0 | 13.4 | 5.5 | 17.3 | Yes | |
| 3 | 1.08 | 100 | 108.0 | 11.4 | 5.5 | 21.6 | Yes | |
| 4 | 0.91 | 100 | 91.0 | 13.3 | 5.5 | 16.9 | Yes | |
| 5 | 0.98 | 100 | 98.0 | 14.3 | 5.6 | 16.5 | Yes | |
| 6 | 1.00 | 100 | 100.0 | 14.4 | 5.4 | 15.4 | Yes | |
| 7 | 1.05 | 100 | 105.0 | 14.2 | 5.5 | 16.4 | Yes | |
| 8 | 0.95 | 100 | 95.0 | 13.1 | 5.7 | 18.7 | Yes | |
| 9 | 1.10 | 100 | 110.0 | 13.1 | 5.4 | 17.3 | Yes | |
| 10 | 0.94 | 100 | 94.0 | 12.0 | 5.5 | 20.7 | Yes | |
| 11 | 0.98 | 100 | 98.0 | 13.9 | 5.5 | 16.4 | Yes | |
| 12 | 0.50 | 100 | 50.0 | 12.1 | 5.4 | 19.3 | Yes | |
| 13 | 1.06 | 100 | 106.0 | 14.0 | 5.4 | 15.9 | Yes | |
| 14 | 0.71 | 100 | 71.0 | 13.6 | 5.5 | 16.2 | Yes | |
| 15 | 1.25 | 100 | 125.0 | 12.7 | 5.5 | 18.3 | Yes | |
| 16 | 1.55 | 100 | 155.0 | 12.6 | 5.5 | 19.8 | Yes | |
| 17 | 1.43 | 100 | 143.0 | 12.6 | 5.4 | 18.5 | Yes | |
| 18 | 1.06 | 100 | 106.0 | 13.6 | 5.5 | 17.0 | Yes | |
| 19 | 2.00 | 100 | 200.0 | 15.7 | 5.4 | 16.2 | Yes | |
| 20 | 2.00 | 100 | 200.0 | 15.8 | 5.4 | 15.9 | Yes | |
| 21 | 2.00 | 100 | 200.0 | 16.2 | 5.6 | 16.5 | Yes | |
| 22 | 1.89 | 100 | 189.0 | 14.5 | 5.4 | 17.3 | Yes | |
| 23 | 0.73 | 100 | 73.0 | 15.3 | 5.3 | 13.7 | Yes | |
| 24 | 0.62 | 100 | 62.0 | 15.2 | 5.6 | 15.2 | Yes | |
| 25 | 0.50 | 100 | 50.0 | 13.6 | 5.4 | 15.5 | Yes | |
| 26 | 0.50 | 100 | 50.0 | 15.3 | 5.6 | 14.8 | Yes | |
| 27 | 0.52 | 100 | 52.0 | 15.1 | 5.5 | 14.8 | Yes | |
| 28 | 0.54 | 100 | 54.0 | 15.2 | 5.6 | 14.9 | Yes | |
| 29 | 0.58 | 100 | 58.0 | 15.0 | 5.5 | 14.8 | Yes | |
| 30 | 0.60 | 100 | 60.0 | 14.7 | 5.6 | 15.7 | Yes | |
| 31 | | | | | | | | |
| 2 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day. | | | | | | | Revised February 2012 | |
| PAGE 2 of 2 | | | | | | | | |