


OHA - Drinking Water Program - Surface Water Quality Data Form					County:	Lane
Cartridge or Bag Filtration					Month/Year:	August 2022
System Name:	Woahink Lake Suites			ID#: 4194188	WTP ID:	WTP-A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1			8.00		0.27	
2			8.00		0.30	
3			9.00		0.33	
4			9.00		0.18	
5			9.00		0.86	
6			9.00		0.26	
7			9.00		0.26	
8			9.00		0.21	
9			9.00		0.27	
10			9.00		0.25	
11			9.00		0.25	
12			9.00		0.33	
13			10.00		0.75	
14			10.00		0.32	
15			10.00		0.30	
16			10.00		0.27	
17			10.00		0.41	
18			10.00		0.28	
19			10.00		0.41	
20			10.00		0.48	
21			10.00		0.27	
22			10.00		0.26	
23			10.00		0.45	
24			11.00		0.31	
25			11.00		0.30	
26			11.00		0.26	
27			11.00		0.27	
28			11.00		0.29	
29			12.00		0.29	
30			12.00		0.27	
31			12.00		0.30	
Cartridge & Bag Filtration				Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				Yes	Yes	Yes
Notes: PSI = pounds per square inch				PRINTED NAME: Dan Reitz		
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE: 		DATE: 09/09/2022
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				PHONE #: (541) 342-1718		CERT #: D&T 6528

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - A	
System Name:	Woahink Lake Suites		ID#: 4194188		Month/Year:	August 2022	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.76	100	76.0	71.0	5.5	-0.4	Yes	
2	0.70	100	70.0	72.8	5.4	-0.5	Yes	
3	0.55	100	55.0	72.1	5.5	-0.4	Yes	
4	1.00	100	100.0	70.3	5.5	-0.4	Yes	
5	0.83	100	83.0	72.4	5.3	-0.5	Yes	
6	0.88	100	88.0	71.8	5.3	-0.4	Yes	
7	0.74	100	74.0	69.3	5.4	-0.4	Yes	
8	0.95	100	95.0	70.0	5.3	-0.4	Yes	
9	0.50	100	50.0	72.0	5.4	-0.4	Yes	
10	0.52	100	52.0	70.3	5.5	-0.4	Yes	
11	2.00	100	200.0	71.7	5.5	-0.4	Yes	
12	1.89	100	189.0	72.9	5.5	-0.4	Yes	
13	1.86	100	186.0	73.9	5.7	-0.4	Yes	
14	1.49	100	149.0	70.7	5.5	-0.4	Yes	
15	1.33	100	133.0	72.0	5.4	-0.4	Yes	
16	1.16	100	116.0	69.8	5.6	-0.3	Yes	
17	1.13	100	113.0	69.7	6.1	-0.2	Yes	
18	0.50	100	50.0	70.7	6.0	-0.3	Yes	
19	0.50	100	50.0	71.9	5.4	-0.5	Yes	
20	0.50	100	50.0	72.0	5.6	-0.4	Yes	
21	0.55	100	55.0	71.4	5.4	-0.4	Yes	
22	0.52	100	52.0	71.5	5.6	-0.4	Yes	
23	0.50	100	50.0	71.2	5.6	-0.4	Yes	
24	1.55	100	155.0	69.0	5.8	-0.2	Yes	
25	1.40	100	140.0	68.5	5.6	-0.3	Yes	
26	1.00	100	100.0	69.0	5.5	-0.3	Yes	
27	0.50	100	50.0	70.3	5.6	-0.4	Yes	
28	2.00	100	200.0	70.3	5.5	-0.3	Yes	
29	1.45	100	145.0	69.9	5.7	-0.3	Yes	
30	2.00	100	200.0	68.4	5.8	-0.2	Yes	
31	1.95	100	195.0	68.4	5.9	-0.2	Yes	
2 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.							Revised February 2012	
PAGE 2 of 2								

DAY	Farenheit	Celcius	Celcius	Farenheit
1	57.0	13.9		32
2	58.1	14.5		32
3	56.7	13.7		32
4	59.0	15.0		32
5	55.8	13.2		32
6	55.7	13.2		32
7	59.6	15.3		32
8	57.0	13.9		32
9	58.8	14.9		32
10	55.7	13.2		32
11	57.1	13.9		32
12	57.9	14.4		32
13	59.3	15.2		32
14	58.5	14.7		32
15	59.0	15.0		32
16	61.2	16.2		32
17	61.9	16.6		32
18	61.3	16.3		32
19	64.0	17.8		32
20	63.3	17.4		32
21	62.9	17.2		32
22	60.8	16.0		32
23	61.9	16.6		32
24	60.3	15.7		32
25	61.6	16.4		32
26	61.4	16.3		32
27	60.8	16.0		32
28	61.7	16.5		32
29	60.9	16.1		32
30	60.7	15.9		32
31	61.0	16.1		32