


OHA - Drinking Water Program - Surface Water Quality Data Form					County:	Lane
Cartridge or Bag Filtration					Month/Year:	June 2023
System Name:	Woahink Lake Suites			ID#: 4194188	WTP ID:	WTP-A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1			0.00		0.23	
2			0.00		0.26	
3			0.00		0.29	
4			0.00		0.33	
5			0.00		0.38	
6			0.00		0.36	
7			1.00		0.42	
8			1.00		0.36	
9			1.00		0.30	
10			1.00		0.40	
11			1.00		0.39	
12			1.00		0.57	
13			1.00		0.47	
14			1.00		0.34	
15			1.00		0.38	
16			1.00		0.39	
17			1.00		0.31	
18			2.00		0.33	
19			2.00		0.53	
20			2.00		0.34	
21			2.00		0.43	
22			2.00		0.46	
23			2.00		0.48	
24			2.00		0.51	
25			2.00		0.42	
26			2.00		0.44	
27			2.00		0.44	
28			2.00		0.42	
29			2.00		0.55	
30			2.00		0.32	
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?				Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				Yes	Yes	Yes
Notes: PSI = pounds per square inch					PRINTED NAME: Dan Reitz	
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: 	DATE: 07/10/2023
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					PHONE #: (541) 342-1718	CERT #: D&T 6528

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - A	
System Name:	Woahink Lake Suites		ID#: 4194188		Month/Year:	June 2023	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.58	100	58.0	16.2	5.6	14.2	Yes	
2	0.56	100	56.0	17.8	5.8	13.4	Yes	
3	0.55	100	55.0	25.0	6.0	9.0	Yes	
4	0.53	100	53.0	17.7	5.3	11.3	Yes	
5	0.51	100	51.0	19.4	5.3	10.0	Yes	
6	0.50	100	50.0	16.7	5.3	12.0	Yes	
7	0.50	100	50.0	18.6	5.7	12.3	Yes	
8	1.40	100	140.0	18.1	6.5	19.2	Yes	
9	1.15	100	115.0	19.1	6.1	15.0	Yes	
10	1.00	100	100.0	19.3	5.8	12.9	Yes	
11	0.50	100	50.0	19.4	6.2	14.1	Yes	
12	0.63	100	63.0	19.3	6.0	13.4	Yes	
13	0.50	100	50.0	20.0	5.9	12.1	Yes	
14	0.88	100	88.0	19.9	5.7	11.8	Yes	
15	0.98	100	98.0	18.6	5.6	12.5	Yes	
16	1.00	100	100.0	18.9	5.1	10.1	Yes	
17	0.86	100	86.0	20.3	5.7	11.4	Yes	
18	0.92	100	92.0	19.8	5.9	12.9	Yes	
19	0.99	100	99.0	20.5	6.0	12.8	Yes	
20	0.84	100	84.0	19.7	6.2	14.4	Yes	
21	0.50	100	50.0	19.9	6.1	13.1	Yes	
22	1.06	100	106.0	19.2	6.0	14.2	Yes	
23	1.07	100	107.0	20.5	5.5	10.7	Yes	
24	1.13	100	113.0	18.2	5.9	14.7	Yes	
25	1.06	100	106.0	20.2	5.8	12.2	Yes	
26	1.07	100	107.0	20.1	6.1	13.8	Yes	
27	1.10	100	110.0	17.8	5.5	12.9	Yes	
28	0.86	100	86.0	20.4	5.8	11.8	Yes	
29	0.89	100	89.0	20.7	5.7	11.2	Yes	
30	0.50	100	50.0	20.6	5.6	10.3	Yes	
2 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.							Revised February 2012	
PAGE 2 of 2								