

OHA - Drinking Water Program - Surface Water Quality Data Form						County:	Lane
Cartridge or Bag Filtration						Month/Year:	January 2025
System Name:	Woahink Lake Suites			ID#: 4194188		WTP ID: WTP-A	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]	
1			2.00		0.06		
2			2.00		0.07		
3			2.00		0.20		
4			3.00		0.19		
5			3.00		0.09		
6			3.00		0.10		
7			3.00		0.10		
8			3.00		0.12		
9			3.00		0.11		
10			3.00		0.07		
11			3.00		0.08		
12			3.00		0.07		
13			3.00		0.08		
14			3.00		0.09		
15			3.00		0.08		
16			3.00		0.09		
17			3.00		0.08		
18			3.00		0.09		
19			4.00		0.18		
20			4.00		0.08		
21			4.00		0.08		
22			4.00		0.08		
23			4.00		0.08		
24			4.00		0.13		
25			4.00		0.07		
26			4.00		0.13		
27			4.00		0.10		
28			4.00		0.09		
29			4.00		0.07		
30			4.00		0.11		
31			4.00		0.10		
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?				Yes	Yes	Yes	
Notes: PSI = pounds per square inch					PRINTED NAME: Dan Reitz		
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: 		2/5/2025
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					PHONE #: (541) 342-1718		CERT #: D&T 6528

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	
System Name:	Woahink Lake Suites		ID#: 4194188		Month/Year:	January 2025	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.61	100	161.0	18.3	6.5	19.6	Yes	
2	1.96	100	195.8	18.9	6.1	16.6	Yes	
3	1.71	100	171.0	17.2	6.6	21.8	Yes	
4	1.48	100	148.0	17.8	6.2	17.9	Yes	
5	1.40	100	140.0	18.3	6.3	17.3	Yes	
6	1.62	100	162.0	17.8	6.3	18.3	Yes	
7	1.38	100	138.0	18.3	6.3	17.4	Yes	
8	1.11	100	111.0	18.9	6.2	15.9	Yes	
9	1.68	100	168.0	18.9	6.0	15.7	Yes	
10	1.74	100	174.0	18.3	5.8	15.0	Yes	
11	1.94	100	194.0	19.4	5.6	13.4	Yes	
12	1.74	100	174.0	20.0	5.6	12.3	Yes	
13	1.96	100	196.0	18.9	6.3	17.8	Yes	
14	1.52	100	152.0	18.3	6.3	17.7	Yes	
15	1.65	100	165.0	18.9	5.4	12.4	Yes	
16	1.77	100	177.0	18.9	5.8	14.3	Yes	
17	1.87	100	187.0	18.3	6.2	17.8	Yes	
18	1.78	100	178.0	18.9	5.3	12.0	Yes	
19	2.08	100	208.0	18.3	5.2	12.5	Yes	
20	1.98	100	198.0	17.8	6.8	23.3	Yes	
21	1.72	100	172.0	18.3	6.0	16.1	Yes	
22	1.52	100	152.0	18.3	5.7	13.9	Yes	
23	1.58	100	158.0	17.2	6.3	19.4	Yes	
24	1.23	100	123.0	17.2	6.2	18.1	Yes	
25	1.49	100	149.0	17.2	6.1	17.4	Yes	
26	1.43	100	143.0	17.8	6.2	17.4	Yes	
27	1.53	100	153.0	18.3	6.0	15.6	Yes	
28	1.53	100	153.0	17.8	5.5	13.7	Yes	
29	1.14	100	114.0	18.3	5.8	14.2	Yes	
30	1.12	100	112.0	17.8	5.3	11.9	Yes	
31	0.68	100	68.0	18.3	5.5	12.0	Yes	
2 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.							Revised February 2012	
PAGE 2 of 2								