

OHA - Drinking Water Program - Surface Water Quality Data Form						County:	Lane
Cartridge or Bag Filtration						Month/Year:	March 2025
System Name:	Woahink Lake Suites			ID#: 4194188		WTP ID: WTP-A	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]	
1			5.00		0.08		
2			5.00		0.04		
3			5.00		0.05		
4			5.00		0.07		
5			5.00		0.08		
6			5.00		0.05		
7			5.00		0.08		
8			5.00		0.09		
9			5.00		0.10		
10			5.00		0.08		
11			5.00		0.06		
12			5.00		0.06		
13			5.00		0.06		
14			5.00		0.05		
15			5.00		0.07		
16			5.00		0.04		
17			5.00		0.05		
18			5.00		0.06		
19			5.00		0.07		
20			5.00		0.04		
21			5.00		0.05		
22			6.00		0.09		
23			6.00		0.07		
24			6.00		0.60		
25			6.00		0.05		
26			6.00		0.09		
27			6.00		0.07		
28			6.00		0.07		
29			6.00		0.08		
30			6.00		0.11		
31			6.00		0.12		
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?				Yes	Yes	Yes	
Notes: PSI = pounds per square inch					PRINTED NAME: Dan Reitz		
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: 		3/31/2025
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					PHONE #: (541) 342-1718		CERT #: D&T 6528

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - : A	
System Name:	Woahink Lake Suites		ID#: 4194188		Month/Year:	March 2025	Disinfection Giardia Log Inactiv:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.57	100	157.0	18.3	5.8	14.8	Yes	
2	1.55	100	155.0	18.3	6.0	15.9	Yes	
3	1.66	100	166.0	18.3	6.4	18.5	Yes	
4	1.39	100	139.0	18.3	5.9	15.0	Yes	
5	1.02	100	102.0	18.3	5.7	13.3	Yes	
6	0.89	100	89.0	18.3	3.6	5.7	Yes	
7	0.53	100	53.0	17.2	6.2	16.4	Yes	
8	0.50	100	50.0	17.2	5.9	14.6	Yes	
9	0.81	100	81.0	17.8	5.7	13.5	Yes	
10	0.74	100	74.0	17.8	5.9	14.5	Yes	
11	1.65	100	165.0	18.3	6.0	16.1	Yes	
12	1.69	100	169.0	18.3	5.9	15.6	Yes	
13	1.58	100	158.0	18.3	3.7	6.5	Yes	
14	1.71	100	171.0	19.4	5.6	12.9	Yes	
15	1.75	100	175.0	17.0	6.0	17.8	Yes	
16	1.65	100	165.0	18.9	6.5	18.7	Yes	
17	1.50	100	150.0	18.9	5.3	11.7	Yes	
18	1.25	100	125.0	18.3	5.7	13.7	Yes	
19	1.05	100	105.0	18.3	5.4	11.9	Yes	
20	0.90	100	90.0	17.8	6.2	16.5	Yes	
21	0.83	100	83.0	17.2	6.1	16.4	Yes	
22	0.50	100	50.0	17.8	6.0	14.6	Yes	
23	0.58	100	58.0	17.2	6.3	17.2	Yes	
24	0.50	100	50.0	16.7	5.9	15.2	Yes	
25	0.52	100	52.0	16.7	6.4	18.4	Yes	
26	0.54	100	54.0	17.2	5.9	14.7	Yes	
27	0.57	100	57.0	16.7	6.2	17.2	Yes	
28	0.66	100	66.0	17.2	5.9	14.9	Yes	
29	0.68	100	68.0	17.2	5.9	14.9	Yes	
30	0.63	100	63.0	17.2	5.8	14.3	Yes	
31	0.50	100	50.0	17.2	5.7	13.5	Yes	
2 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.							Revised February 2012	
PAGE 2 of 2								