

OHA - Drinking Water Services - Turbidity Monitoring Report Form County:
 Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Butte Creek Scout Ranch ID #: 04191 WTP-: _____ Month/Year: 6/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1					.14		
2					.13		
3					.14		
4					.14		
5					.13		
6					.12		
7					.13		
8					.13		
9					.14		
10					.13		
11					.14		
12					.15		
13					.14		
14					.14		
15					.14		
16					.13		
17					.13		
18					.14		
19					.13		
20					.13		
21					.14		
22					.14		
23					.13		
24					.13		
25					.12		
26					.11		
27					.12		
28					.12		
29					.12		
30					.12		
31					.12		

Slow Sand/Membrane/DE Filtration/Unfiltered Monthly Summary 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: <u>Bill Hood</u>	
	SIGNATURE: <u>Bill Hood</u>	DATE: <u>7/12/2022</u>
	PHONE #: <u>(503) 539-3834</u>	CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Butte Creek Scout Ranch ID #: 94191 WTP-: _____ Month/Year: 6/2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³ ↑	Contact Time (T)	Actual CT	Temp ↓	pH ↑	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[° C]		Use tables	Yes / No	[GPM]
1/	.31	280	86.8	12.4	9.6	70	✓	1.3
2/	.32		89.6	12.8	9.6	70	✓	1.6
3/	.32		89.6	12.9	9.6	70	✓	1.4
4/	.32		89.6	12.8	9.6	70	✓	2.3
5/	.41		114.8	13.2	9.6	70	✓	1.5
6/	.43		120.4	12.9	9.6	73	✓	1.2
7/	.44		123.2	12.9	9.6	73	✓	1.2
8/	.52		145.6	13.5	9.6	73	✓	1.2
9/	.56		156.8	13.6	9.6	73	✓	1.2
10/	.58		162.4	13.8	9.6	73	✓	1.4
11/	.64		179.2	13.8	9.7	75	✓	2.2
12/	.72		201.6	13.2	9.7	75	✓	1.8
13/	.65		182	12.7	9.6	75	✓	1.3
14/	.64		179.2	12.9	9.6	75	✓	2.2
15/	.67		187.6	12.7	9.6	75	✓	1.5
16/	.65		182	13.1	9.7	75	✓	1.4
17/	.69		193.2	12.8	9.7	75	✓	2.1
18/	.69		193.2	12.8	9.6	75	✓	2.0
19/	.67		187.6	12.8	9.7	75	✓	2.4
20/	.68		190.4	13	9.7	75	✓	2.8
21/	.67		187.6	14	9.7	75	✓	2.5
22/	.67		187.6	13.9	9.7	75	✓	2.7
23/	.65		182	13.7	9.7	75	✓	2.3
24/	.65		182	14	9.7	75	✓	3.4
25/	.57		159.6	15	9.7	75	✓	4.4
26/	.33		92.4	15.7	9.6	70	✓	3.0
27/	.35		98	16.1	9.6	70	✓	2.4
28/	.34		95.2	15.7	9.6	70	✓	1.9
29/	.33		92.4	15.5	9.6	70	✓	1.9
30/	.34		95.2	15	9.6	70	✓	2.0
31/	.56		156.8	15	9.7	73	✓	8.5

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised September 2016
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/urb-alt-unfiltered.pdf

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350