

OHA - Drinking Water Services - Turbidity Monitoring Report Form County:
 Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Batte Creek Scout Ranch ID #: 94191 WTP-: _____ Month/Year: 4/24

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2					.11		
3					.12		
4					.12		
5					.11		
6					.11		
7					.10		
8					.11		
9					.11		
10					.11		
11					.15		
12					.14		
13					.11		
14					.11		
15					.10		
16					.11		
17					.11		
18					.12		
19					.13		
20					.10		
21					.11		
22					.11		
23					.11		
24					.11		
25					.11		
26					.13		
27					.11		
28					.11		
29					.11		
30					.13		
31					.12		

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? ² Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Notes:

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: Bill Hood

SIGNATURE: Bill Hood DATE: 5/10/2024

PHONE #: (503) 539-9834 CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name:

Butte Creek Scout Ranch

ID #: 94191

WTP-:

Month/Year:

4/24

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/	.32	280	89	8.8	7.4	55	Y	1.3
2/	.32	280	89	8.0	7.4	55	Y	.9
3/	.35	280	98	8.7	7.4	55	Y	1.1
4/	.35	280	86	8.8	7.4	55	Y	1.3
5/	.37	280	103.6	8.8	7.5	55	Y	.8
6/	.37	280	103	8.8	7.5	55	Y	1.5
7/	.38	280	106	9.1	7.5	55	Y	1.3
8/	.37	280	103	9.2	7.4	55	Y	.8
9/	.40	280	112	8.9	7.4	55	Y	1.1
10/	.39	280	109	9.3	7.5	55	Y	.9
11/	.41	280	114	9.7	7.4	55	Y	.8
12/	.38	280	109	10	7.5	55	Y	1.2
13/	.41	280	114	10	7.5	55	Y	2.3
14/	.48	280	134	10.7	7.5	57	Y	1.4
15/	.45	280	126	10.4	7.5	57	Y	1.6
16/	.47	280	131	10.1	7.5	57	Y	1.4
17/	.47	280	131	9.7	7.5	57	Y	1.0
18/	.43	280	120	9.9	7.5	57	Y	1.0
19/	.46	280	128	11	7.5	57	Y	1.4
20/	.44	280	123	10.9	7.6	57	Y	2.4
21/	.51	280	142	10.5	7.6	57	Y	2.3
22/	.55	280	154	10.4	7.6	57	Y	1.5
23/	.53	280	148	11.1	7.6	57	Y	1.2
24/	.50	280	140	10.8	7.6	57	Y	1.4
25/	.52	280	145	14.6	7.6	57	Y	2.1
26/	.51	280	142	10.9	7.6	57	Y	2.4
27/	.56	280	156	10.7	7.6	57	Y	3.6
28/	.49	280	137	15.6	7.6	57	Y	1.8
29/	.42	280	117	19.9	7.7	57	Y	.21
30/	.37	280	103	21.2	7.7	55	Y	.2
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised September 2016

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350