

OHA - Drinking Water Services - Turbidity Monitoring Report Form County:
 Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Batte Creek Scoat Ranch ID #: 9419 WTP-: _____ Month/Year: 7/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2					.15		
3					.12		
4					.12		
5					.11		
6					.14		
7					.13		
8					.12		
9					.12		
10					.13		
11					.12		
12					.12		
13					.13		
14					.14		
15					.14		
16					.13		
17					.13		
18					.10		
19					.09		
20					.08		
21					.08		
22					.08		
23					.07		
24					.12		
25					.09		
26					.11		
27					.10		
28					.12		
29					.13		
30					.13		
31					.17		

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary

95% of daily turbidity readings ≤ 1 NTU? ² Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

Notes:

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: Bill Hood

SIGNATURE: Bill Hood DATE: 8/16/2024

PHONE #: (503) 539-3834 CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name:

Batte Creek Scout Ranch

ID #:

94191

WTP-:

Month/Year:

7/2024

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³ ₁	Contact Time (T)	Actual CT	Temp ✓	pH 1	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/	.45	280	126	15.6	6.9	24	Y	1.5
2/	.42	280	117.6	15.7	6.9	24	Y	2.4
3/	.42	280	117.6	15.6	6.9	24	Y	2.8
4/	.42	280	117.6	15.9	6.9	24	Y	2.0
5/	.43	280	120.4	16.6	6.9	24	Y	2.9
6/	.43	280	120.4	16.9	6.9	24	Y	2.4
7/	.45	280	126	17.5	6.9	24	Y	4.7
8/	.44	280	123.2	17.9	6.7	24	Y	4.9
9/	.47	280	131.6	18.2	6.8	24	Y	2.2
10/	.40	280	112	18.3	6.9	24	Y	3.1
11/	.38	280	106.4	18	6.9	23	Y	5.2
12/	.39	280	109.2	17.7	6.9	23	Y	5.5
13/	.37	280	103.6	17.7	6.8	23	Y	3.7
14/	.34	280	95.2	17.9	6.8	23	Y	4.9
15/	.34	280	95.2	17.6	6.8	23	Y	5.4
16/	.33	280	92.4	17.7	6.9	23	Y	3.8
17/	.34	280	95.2	17	6.9	23	Y	3.4
18/	.32	280	89.6	16.3	6.8	23	Y	5.4
19/	.31	280	86.8	16.4	6.8	23	Y	5.8
20/	.34	280	95.2	16.4	6.8	23	Y	5.2
21/	.44	280	123.2	17.3	6.9	24	Y	6.5
22/	.46	280	128.2	16.8	6.9	24	Y	5.7
23/	.51	280	142.8	15.4	6.9	24	Y	4.3
24/	.56	280	156.8	15.3	6.9	24	Y	5.3
25/	.52	280	145.6	15.9	6.8	24	Y	5.4
26/	.53	280	148.4	14.9	6.9	24	Y	6.4
27/	.63	280	176.4	14.7	6.9	24	Y	4.2
28/	.62	280	173.6	14.9	6.8	24	Y	5.5
29/	.53	280	148.4	15.2	6.8	24	Y	5.7
30/	.50	280	140	15.6	6.9	24	Y	3.4
31/	.50	280	140	15.1	6.9	24	Y	3.2

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised September 2016

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/urb-alt-unfiltere-l.pdf

Return by 10th of following month by email, fax, or mail to:

dlw.dmcce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350