

OHA - Drinking Water Services - Turbidity Monitoring Report Form County:
 Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Batte Creek Scout Ranch ID #: 94191 WTP: _____ Month/Year: 8/2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2					.16		
3					.14		
4					.14		
5					.14		
6					.13		
7					.13		
8					.10		
9					.10		
10					.09		
11					.09		
12					.09		
13					.08		
14					.08		
15					.08		
16					.08		
17					.08		
18					.08		
19					.08		
20					.08		
21					.08		
22					.08		
23					.08		
24					.08		
25					.08		
26					.08		
27					.08		
28					.08		
29					.08		
30					.08		
31					.08		

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No		CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:		PRINTED NAME: <u>B:ll Hood</u>	
		SIGNATURE: <u>B:ll Hood</u>	DATE: <u>9/9/2024</u>
		PHONE #: <u>(503) 539-3834</u>	CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Battle Creek Scout Ranch ID #: 94191 WTP.: _____ Month/Year: 8/2024

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]	6.8	Use tables	Yes / No	[GPM]
1/	.46	280	128	17	6.8	24	✓	5.2
2/	.47		131	18	6.8	24	✓	5.9
3/	.51		142	18	6.8	24	✓	4.1
4/	.46		128	18	6.9	24	✓	6.1
5/	.48		134	18	6.9	24	✓	5.9
6/	.45		126	17	6.9	24	✓	4.9
7/	.46		128	17	6.9	24	✓	5.1
8/	.46		128	17	6.8	24	✓	5.5
9/	.45		126	17	6.9	24	✓	6.6
10/	.42		117.6	17	6.9	24	✓	4.5
11/	.57		159	17	6.9	24	✓	5.8
12/	.67		187	17	6.9	24	✓	4.4
13/	.76		212	16	6.9	24	✓	3.5
14/	.75		210	16	7.0	24	✓	3.3
15/	.77		215	16	7.0	24	✓	2.7
16/	.81		226	16	6.9	24	✓	3.0
17/	.84		235	16	6.9	25	✓	3.7
18/	.69		193	16	6.9	24	✓	3.4
19/	.73		204	16	6.8	24	✓	2.8
20/	.76		212	16.16	6.8	24	✓	3.5
21/	.74		191	16	6.8	24	✓	3.5
22/	.71		198	16	6.8	24	✓	4.2
23/	.69		193	16	6.8	24	✓	3.7
24/	.68		190	15	6.8	24	✓	3.9
25/	.65		182	15	6.9	24	✓	4.9
26/	.57		159	15	6.9	24	✓	2.4
27/	.56		156	15	6.9	24	✓	2.3
28/	.55		194	15	6.9	24	✓	2.5
29/	.65		182	15	6.9	24	✓	2.7
30/	.64		179	15	6.9	24	✓	2.4
31/	.64		179	15	6.8	24	✓	2.8

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised September 2016
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/urb-alt-unfiltered.pdf

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350