

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Clackamas
Month/Year: Jul-25

System Name: Butte Creek Scout Ranch		ID#: 41 941		WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.07		
2					0.07		
3					0.07		
4					0.07		
5					0.07		
6					0.07		
7					0.07		
8					0.07		
9					0.07		
10					0.07		
11					0.07		
12					0.07		
13					0.07		
14					0.07		
15					0.07		
16					0.07		
17					0.07		
18					0.07		
19					0.07		
20					0.07		
21					0.07		
22					0.07		
23					0.07		
24					0.07		
25					0.07		
26					0.07		
27					0.07		
28					0.07		
29					0.07		
30					0.07		
31					0.07		

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
Notes:		PRINTED NAME: Bill Hood	
		SIGNATURE:	8/5/2025
		PHONE #: (503)539-3834	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- :
System Name: Butte Creek Scout Ranch ID#: 41

Month/Year: Jul-25

Disinfection *Giardia* Log Inactiv:
1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.57	280	159.6	16.0	7.10	25.2	YES	4.9.07
2	0.53	280	148.4	16.0	7.10	25.1	YES	5.7
3	0.64	280	179.2	16.0	7.10	25.4	YES	5.4
4	0.68	280	190.4	16.0	7.10	25.5	YES	4.6
5	0.68	280	190.4	15.0	7.00	26.3	YES	4.9
6	0.68	280	190.4	15.0	7.00	26.3	YES	4.9
7	0.69	280	193.2	16.0	7.10	25.5	YES	6.3
8	0.71	280	198.8	16.0	7.10	25.6	YES	4.8
9	0.68	280	190.4	17.0	7.10	23.8	YES	6.6
10	0.67	280	187.6	17.0	7.10	23.8	YES	7.1
11	0.71	280	198.8	17.0	7.10	23.9	YES	6.7
12	0.71	280	198.8	17.0	7.10	23.9	YES	6.6
13	0.73	280	204.4	18.0	7.10	22.4	YES	7.4
14	0.71	280	198.8	18.0	7.20	23.2	YES	7.7
15	0.7	280	196.0	18.0	7.10	22.3	YES	5.1
16	0.66	280	184.8	18.0	7.10	22.2	YES	6.3
17	0.64	280	179.2	18.0	7.20	23.0	YES	7.9
18	0.67	280	187.6	18.0	7.20	23.1	YES	7.2
19	0.63	280	176.4	17.6	7.20	23.6	YES	6.2
20	0.62	280	173.6	17.0	7.20	24.6	YES	7.4
21	0.64	280	179.2	17.0	7.20	24.6	YES	7.4
22	0.65	280	182.0	17.0	7.20	24.7	YES	5.3
23	0.61	280	170.8	17.0	7.20	24.5	YES	4.5
24	0.6	280	168.0	17.0	7.20	24.5	YES	5.2
25	0.6	280	168.0	17.0	7.20	24.5	YES	5
26	0.59	280	165.2	17.0	7.20	24.5	YES	5.2
27	0.62	280	173.6	17.0	7.20	24.6	YES	7.1
28	0.64	280	179.2	17.0	7.20	24.6	YES	7.6
29	0.63	280	176.4	17.0	7.20	24.6	YES	5.3
30	0.61	280	170.8	17.0	7.20	24.5	YES	5.9
31	0.61	280	170.8	17.0	7.20	24.5	YES	7.6

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmcce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350