

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Clackamas
Month/Year: Oct./2025

System Name:		Butte Creek Scout Ranch			ID#: 41	94191		WTP : TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1					0.07			
2					0.07			
3					0.07			
4					0.07			
5					0.07			
6					0.07			
7					0.07			
8					0.07			
9					0.07			
10					0.07			
11					0.07			
12					0.07			
13					0.07			
14					0.07			
15					0.07			
16					0.07			
17					0.07			
18					0.07			
19					0.07			
20					0.07			
21					0.07			
22					0.07			
23					0.07			
24					0.07			
25					0.07			
26					0.07			
27					0.07			
28					0.07			
29					0.07			
30					0.07			
31					0.07			

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes	Yes	Yes
Notes:		Bill Hood	
		SIGNATURE:	DATE: 11.6.25
		PHONE #: (503)539-3834	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- :
System Name:
ID#: 41
94191
Month/Year: Oct./2025
Disinfection *Giardia* Log
Inactiv:
1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.37	280	103.6	10.7	7.40	39.5	YES	0.9
2	0.51	280	142.8	13.6	7.30	31.6	YES	1.4
3	0.54	280	151.2	13.4	7.30	32.1	YES	2.1
4	0.55	280	154.0	13.6	7.30	31.8	YES	2.8
5	0.56	280	156.8	13.6	7.30	31.8	YES	2.7
6	0.55	280	154.0	13.0	7.30	33.1	YES	1
7	0.54	280	151.2	12.5	7.30	34.1	YES	0.7
8	0.52	280	145.6	12.7	7.30	33.6	YES	0.7
9	0.49	280	137.2	12.7	7.30	33.5	YES	0.8
10	0.47	280	131.6	12.8	7.30	33.2	YES	1.4
11	0.49	280	137.2	12.7	7.30	33.5	YES	2.1
12	0.49	280	137.2	12.3	7.30	34.9	YES	2.6
13	0.54	280	151.2	11.8	7.30	36.2	YES	1.5
14	0.49	280	137.2	11.6	7.40	37.7	YES	0.8
15	0.46	280	128.8	11.2	7.40	38.6	YES	0.9
16	0.41	280	114.8	11.0	7.40	38.9	YES	0.7
17	0.37	280	103.6	11.3	7.40	38.0	YES	0.9
18	0.33	280	92.4	10.9	7.40	38.8	YES	1.6
19	0.3	280	84.0	11.3	7.40	37.7	YES	1.2
20	0.3	280	84.0	10.9	7.40	38.7	YES	1
21	0.34	280	95.2	10.5	7.40	39.9	YES	1
22	0.3	280	84.0	10.5	7.40	39.7	YES	1.1
23	0.31	280	86.8	10.8	7.40	39.0	YES	0.8
24	0.31	280	86.8	11.0	7.40	38.5	YES	0.8
25	0.37	280	103.6	10.5	7.40	40.0	YES	1.4
26	0.3	280	84.0	10.0	7.40	41.0	YES	1.3
27	0.33	280	92.4	10.0	7.40	41.2	YES	1
28	0.41	280	114.8	10.1	7.40	41.3	YES	1.3
29	0.31	280	86.8	10.4	7.40	40.0	YES	1
30	0.32	280	89.6	9.4	7.30	41.3	YES	1
31	0.31	280	86.8	9.7	7.30	40.4	YES	1

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp.dmcce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350