

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: [Icon]
 Month/Year: 12/10/2025

System Name: **Butte Creek Scout Ranch** **ID#: 94191** **WTP : TP -**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.08		
2					0.07		
3					0.08		
4					0.08		
5					0.08		
6					0.08		
7					0.08		
8					0.09		
9					0.09		
10					0.09		
11					0.08		
12					0.08		
13					0.08		
14					0.07		
15					0.07		
16					0.07		
17					0.07		
18					0.08		
19					0.08		
20					0.08		
21					0.08		
22					0.08		
23					0.08		
24					0.07		
25					0.07		
26					0.07		
27					0.08		
28					0.08		
29					0.08		
30					0.08		
31					0.08		

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes

Notes:	PRINTED NAME: Bill Hood	
	SIGNATURE: Bill Hood	DATE: 12/10/2025
	PHONE #: (503)539-3834	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: Butte Creek Scout Ranch **ID#: 41 94191**

Month/Year: Dec-25

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.33	280	92.4	10.5	7.40	39.8	YES	1.2
2	0.34	280	95.2	10.0	7.30	39.8	YES	1.1
3	0.34	280	95.2	9.7	7.30	40.6	YES	0.9
4	0.33	280	92.4	10.4	7.30	38.7	YES	0.8
5	0.32	280	89.6	10.6	7.30	38.2	YES	0.8
6	0.41	280	114.8	10.6	7.30	38.6	YES	0.91
7	0.4	280	112.0	10.6	7.40	39.9	YES	1
8	0.5	280	140.0	10.0	7.40	41.9	YES	2.2
9	0.68	280	190.4	10.1	7.40	42.5	YES	1.3
10	0.65	280	182.0	10.2	7.30	40.7	YES	1
11	0.62	280	173.6	10.4	7.30	40.0	YES	0.8
12	0.62	280	173.6	10.4	7.30	40.0	YES	0.8
13	1	280	280.0	10.6	7.40	42.7	YES	0.9
14	1.1	280	308.0	10.7	7.30	41.4	YES	0.9
15	0.98	280	274.4	11.0	7.30	40.0	YES	1.3
16	0.86	280	240.8	10.6	7.30	40.5	YES	1.2
17	0.74	280	207.2	10.5	7.20	38.9	YES	1
18	0.66	280	184.8	9.4	7.20	41.4	YES	1
19	0.59	280	165.2	8.9	7.20	42.5	YES	1
20	0.52	280	145.6	9.4	7.20	40.8	YES	1
21	0.47	280	131.6	8.8	7.20	42.2	YES	1
22	0.43	280	120.4	8.3	7.10	41.9	YES	1.9
23	0.43	280	120.4	8.6	7.10	41.1	YES	1.7
24	0.42	280	117.6	8.5	7.10	41.3	YES	1.3
25	0.39	280	109.2	8.0	7.10	42.5	YES	1.1
26	0.41	280	114.8	8.7	7.10	40.7	YES	2.1
27	0.4	280	112.0	8.9	7.10	40.1	YES	1.3
28	0.4	280	112.0	9.2	7.10	39.4	YES	1.4
29	0.37	280	103.6	8.4	7.10	41.3	YES	1
30	0.32	280	89.6	8.4	7.10	41.1	YES	0.7
31	0.29	280	81.2	7.5	7.10	43.5	YES	1

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dpw.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350