

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Clackamas**
 Month/Year: **Dec-25**

System Name: Butte Creek Scout Ranch		ID#: 41 94191		WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.08		
2					0.08		
3					0.08		
4					0.08		
5					0.07		
6					0.07		
7					0.07		
8					0.07		
9					0.08		
10					0.08		
11					0.09		
12					0.09		
13					0.08		
14					0.08		
15					0.07		
16					0.07		
17					0.08		
18					0.08		
19					0.08		
20					0.08		
21					0.08		
22					0.11		
23					0.17		
24					0.26		
25					0.15		
26					0.12		
27					0.11		
28					0.10		
29					0.09		
30					0.09		
31					0.08		

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
Notes:	PRINTED NAME: Bill Hood		
	SIGNATURE: Bill Hood		DATE: 1/5/2026
	PHONE #: (503)539-3834		CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: **Butte Creek Scout**

ID#: **41 94191**

Month/Year: **Dec-25**

Disinfection *Giardia* Log
Inactiv: **1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.3	280	84.0	7.5	7.10	43.5	YES	1
2	0.3	280	84.0	8.1	7.10	41.8	YES	1.1
3	0.3	280	84.0	7.4	7.10	43.8	YES	1.8
4	0.4	280	112.0	7.5	7.10	44.0	YES	1.1
5	0.4	280	112.0	8.4	7.20	43.0	YES	1.1
6	0.5	280	140.0	8.5	7.20	43.2	YES	1.21
7	0.6	280	168.0	8.6	7.20	43.4	YES	0.9
8	0.6	280	168.0	9.2	7.20	41.7	YES	1
9	0.6	280	168.0	9.2	7.20	41.7	YES	1
10	0.6	280	168.0	9.9	7.20	39.8	YES	1
11	0.6	280	168.0	10.1	7.30	40.7	YES	1.1
12	0.5	280	140.0	9.5	7.20	40.4	YES	1
13	0.7	280	196.0	9.0	7.20	42.7	YES	1.8
14	0.7	280	196.0	9.0	7.20	42.7	YES	8.7
15	0.9	280	252.0	10.0	7.20	40.9	YES	1
16	0.9	280	252.0	10.0	7.20	40.9	YES	1
17	0.8	280	224.0	10.0	7.10	39.1	YES	0.6
18	0.6	280	168.0	9.0	7.10	40.8	YES	1.8
19	0.4	280	112.0	9.2	7.10	39.4	YES	1
20	0.4	280	112.0	8.8	7.10	40.4	YES	0.9
21	0.4	280	112.0	8.8	7.10	40.4	YES	0.9
22	0.3	280	84.0	8.6	7.10	40.5	YES	0.9
23	0.3	280	84.0	8.5	7.10	40.7	YES	0.9
24	0.3	280	84.0	8.3	7.10	41.3	YES	0.9
25	0.3	280	84.0	8.0	7.10	42.1	YES	0.9
26	0.3	280	84.0	8.0	7.00	40.7	YES	1
27	0.3	280	84.0	7.7	7.00	41.5	YES	1
28	0.3	280	84.0	7.1	7.00	43.1	YES	1
29	0.2	280	56.0	6.8	7.00	43.5	YES	0.9
30	0.2	280	56.0	6.5	7.00	44.4	YES	0.8
31	0.2	280	56.0	6.2	7.00	45.3	YES	1

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dpw.dmcce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350