

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Clackamas**
 Month/Year: **Jan-26**

System Name: Butte Creek Scout Ranch		ID#: 41 94191		WTP : TP -			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.08		
2					0.08		
3					0.08		
4					0.07		
5					0.80		
6					0.80		
7					0.80		
8					0.12		
9					0.12		
10					0.12		
11					0.10		
12					0.09		
13					0.08		
14					0.08		
15					0.08		
16					0.08		
17					0.08		
18					0.08		
19					0.07		
20					0.08		
21					0.08		
22					0.08		
23					0.08		
24					0.08		
25					0.07		
26					0.07		
27					0.08		
28					0.08		
29					0.08		
30					0.07		
31					0.07		

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes

Notes:	Bill Hood	
	Bill Hood	DATE: 2/6/2026
	PHONE #: (503)539-3834	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: Butte Creek Scout **ID#: 41 94191** **Month/Year: Jan-26** **Disinfection *Giardia* Log Inactiv:** 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.2	280	56.0	6.4	7.00	44.7	YES	1
2	0.2	280	56.0	7.5	7.00	41.5	YES	0.9
3	0.2	280	56.0	7.5	7.00	41.5	YES	0.9
4	0.2	280	56.0	7.7	7.00	41.0	YES	0.9
5	0.2	280	56.0	7.2	7.00	42.4	YES	1
6	0.2	280	56.0	6.8	7.00	43.5	YES	0.9
7	0.2	280	56.0	6.7	7.00	43.8	YES	1
8	0.3	280	84.0	6.6	7.10	46.2	YES	1
9	0.5	280	140.0	6.6	7.10	47.2	YES	1
10	0.5	280	140.0	6.4	7.10	47.9	YES	1.4
11	0.5	280	140.0	6.8	7.10	46.6	YES	1.1
12	0.4	280	112.0	6.7	7.10	46.4	YES	1
13	0.5	280	140.0	6.3	7.10	48.2	YES	1
14	0.7	280	196.0	6.0	7.00	48.5	YES	1.1
15	0.7	280	196.0	6.4	7.00	47.3	YES	1.1
16	0.7	280	196.0	6.2	7.20	51.4	YES	1.1
17	1	280	280.0	6.0	7.20	54.0	YES	2
18	0.9	280	252.0	5.6	7.20	54.8	YES	1.2
19	1	280	280.0	5.3	7.20	56.6	YES	2.5
20	1.1	280	308.0	5.1	7.20	58.0	YES	0.98
21	1.2	280	336.0	4.8	7.20	59.9	YES	1.2
22	1	280	280.0	4.6	7.20	59.3	YES	1
23	0.7	280	196.0	5.2	7.20	55.0	YES	1
24	0.7	280	196.0	4.3	7.20	58.5	YES	1
25	0.7	280	196.0	4.0	7.10	57.5	YES	1
26	0.6	280	168.0	4.4	7.10	55.4	YES	3.3
27	0.6	280	168.0	4.7	7.10	54.3	YES	4.1
28	0.6	280	168.0	4.7	7.20	56.2	YES	1
29	0.5	280	140.0	6.3	7.20	49.9	YES	1
30	0.4	280	112.0	6.4	7.20	49.0	YES	1
31	0.4	280	112.0	6.7	7.20	48.1	YES	1.4

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dpw.dmcce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350