

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Dec. 2021

System Name:	Peel Country Store		ID#: 41	94255	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1					0.037		0.037
2			0.058				0.058
3			0.042				0.042
4			^{BM} 0.059	0.059			0.059
5			0.052				0.052
6			0.038				0.038
7			0.058				0.058
8			0.042				0.042
9			0.040				0.040
10			0.038				0.038
11			0.037				0.037
12			0.062				0.062
13			0.086				0.086
14					0.076		0.076
15						0.073	0.073
16					0.062		0.062
17			0.048				0.048
18					0.063		0.063
19				0.078			0.078
20				0.075			0.075
21					0.054		0.054
22					0.061		0.061
23					0.075		0.075
24					0.078		0.078
25					0.063		0.063
26					0.046		0.046
27					0.048		0.048
28					0.056		0.056
29					0.042		0.042
30					0.054		0.054
31					0.036		0.036

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity reading < IFE 2 triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: Jeremy L Schwab
	SIGNATURE: <i>Jeremy L Schwab</i> DATE: 1-10-22
	PHONE #: 503-310-1680 CERT #: 09180

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	Peel Country Store	ID#: 41	94255	Month/Year: Dec. 2021	WTP - : A	Disinfection Giardia Log Inactiv: 1
--------------	--------------------	---------	-------	-----------------------	-----------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.4	50	70	11.8	6.9	39	Yes	25
2	2.3	↑	115	11.4	6.8	43	Yes	↑
3	2.6	↑	130	11.2	6.8	44	Yes	↑
4	2.7	↑	135	10.4	6.9	45	Yes	↑
5	3.0	↑	150	10.6	6.9	46	Yes	↑
6	2.4	↑	120	10.6	6.8	43	Yes	↑
7	2.3	↑	115	12.0	6.9	43	Yes	↑
8	1.6	↑	80	11.3	6.9	40	Yes	↑
9	2.2	↑	110	10.6	6.8	42	Yes	↑
10	2.9	↑	145	9.5	6.7	46	Yes	↑
11	2.4	↑	120	9.6	6.9	43	Yes	↑
12	1.4	↑	70	10.2	6.7	39	Yes	↑
13	0.7	↑	35	10.0	6.4	31	Yes	↑
14	1.9	↑	95	9.4	6.2	46	Yes	↑
15	2.4	↑	120	11.1	6.4	36	Yes	↑
16	1.5	↑	75	11.7	6.3	33	Yes	↑
17	2.9	↑	145	10.4	6.4	38	Yes	↑
18	0.9	↑	45	11.1	6.5	31	Yes	↑
19	1.4	↑	70	12.8	6.3	33	Yes	↑
20	2.9	↑	145	12.6	6.5	46	Yes	↑
21	0.8	↑	40	12.0	6.6	37	Yes	↑
22	1.9	↑	95	12.7	6.5	41	Yes	↑
23	1.7	↑	85	12.9	6.5	41	Yes	↑
24	1.4	↑	70	9.7	6.6	39	Yes	↑
25	1.8	↑	90	9.8	6.7	41	Yes	↑
26	1.4	↑	70	9.0	6.6	52	Yes	↑
27	1.8	↑	90	9.4	6.7	54	Yes	↑
28	2.9	↑	145	8.7	6.6	61	Yes	↑
29	3.0	↑	150	9.6	6.7	46	Yes	↑
30	2.6	↑	130	9.7	6.6	44	Yes	↑
31	1.7	↓	85	9.9	6.9	41	Yes	↓

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.