

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: October 2022

System Name:	Peel Country Store		ID#: 41	94255	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1						0.051	0.051
2					0.053		0.053
3						0.048	0.048
4						0.051	0.051
5						0.050	0.050
6						0.054	0.054
7					0.051		0.051
8					0.050		0.050
9					0.051		0.051
10					0.052		0.052
11						0.053	0.053
12					0.053		0.053
13						0.052	0.052
14						0.052	0.052
15						0.053	0.053
16						0.050	0.050
17					0.052		0.052
18						0.128	0.128
19						0.059	0.059
20						0.054	0.054
21					0.053	0.8m	0.053
22						0.289	0.289
23					0.062		0.062
24						0.246	0.246
25					0.054		0.054
26						0.055	0.055
27						0.053	0.053
28					0.055		0.055
29						0.051	0.051
30						0.053	0.053
31						0.109	0.109

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity reading < IFE 2 triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
<b>Notes:</b>		PRINTED NAME: Jeremy L Schwab	DATE: 11-7-22
		SIGNATURE: <i>Jeremy L Schwab</i>	CERT #: 09180
		PHONE #: 503-810-1680	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name: Peel Country Store ID#: 41 94255 Month/Year: October 2022 Disinfection Giardia Log Inactiv: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	2.8	50	140	18.3	7.4	36	Yes	25
2	1.8	↑	90	18.7	7.4	33	Yes	↑
3	1.4	↑	70	19.1	7.4	31	Yes	↑
4	2.2	↑	110	18.1	7.4	34	Yes	↑
5	2.3	↑	115	17.3	7.4	35	Yes	↑
6	2.1	↑	105	18.5	7.4	34	Yes	↑
7	1.9	↑	95	18.1	7.4	33	Yes	↑
8	2.1	↑	105	17.9	7.4	34	Yes	↑
9	1.9	↑	95	18.1	7.4	33	Yes	↑
10	2.0	↑	100	17.8	7.4	33	Yes	↑
11	2.6	↑	130	17.8	7.5	36	Yes	↑
12	2.5	↑	125	17.7	7.4	36	Yes	↑
13	1.6	↑	80	17.5	7.4	32	Yes	↑
14	1.8	↑	90	17.6	7.3	33	Yes	↑
15	1.9	↑	95	17.4	7.4	33	Yes	↑
16	1.9	↑	95	16.8	7.3	33	Yes	↑
17	1.8	↑	90	16.4	7.4	33	Yes	↑
18	1.3	↑	65	17.2	7.4	31	Yes	↑
19	1.8	↑	90	16.4	7.4	33	Yes	↑
20	1.8	↑	90	16.0	7.4	33	Yes	↑
21	1.9	↑	95	16.4	7.4	33	Yes	↑
22	1.1	↑	55	15.4	7.2	31.25 <sup>8m</sup>	Yes	↑
23	1.5	↑	75	15.2	7.3	32	Yes	↑
24	0.7	↑	35	14.5	7.2	29	Yes	↑
25	1.5	↑	75	14.8	7.1	32	Yes	↑
26	2.4	↑	120	14.7	7.1	35	Yes	↑
27	2.2	↑	110	14.3	7.2	51	Yes	↑
28	2.7	↑	135	15.0	7.2	36	Yes	↑
29	2.2	↑	110	16.5	7.2	34	Yes	↑
30	2.3	↑	115	15.6	7.3	35	Yes	↑
31	2.0	√	100	16.4	7.3	33	Yes	√

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.