

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Douglas  
 Month/Year: Feb 2023  
 WTP: TP - A

System Name:	Peel Country Store		ID#: 41	94255		WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1						0.053	0.053
2						0.052	0.052
3						0.057	0.057
4						0.052	0.052
5						0.049	0.049
6					0.051		0.051
7						0.053	0.053
8						0.055	0.055
9						0.056	0.056
10						0.114	0.114
11						0.064	0.064
12						0.071	0.071
13					0.055		0.055
14						0.058	0.058
15						0.051	0.051
16						0.075	0.075
17						0.067	0.067
18						0.076	0.076
19						0.068	0.068
20					0.147		0.147
21						0.060	0.060
22						0.062	0.062
23						0.059	0.059
24						0.048	0.048
25						0.054	0.054
26					0.167	0.06m	0.167
27						0.065	0.065
28						0.054	0.054
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity reading < IFE 2 triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:		PRINTED NAME: Jeremy L Schwab	DATE: 3-5-23
		SIGNATURE: <i>Jeremy L Schwab</i>	CERT #: 09180
		PHONE #: 503-310-1680	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))



## OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -: A

System Name: Peel Country Store ID#: 41 94255 Month/Year: Feb. 2023

Disinfection Giardia  
Log Inactiv: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	2.4	50	120	9.8	7.1	52	Yes	25
2	1.9	↑	95	9.7	7.2	50	Yes	↑
3	2.1		105	12.7	7.2	51	Yes	
4	2.2		110	11.3	7.2	51	Yes	
5	1.5		75	11.8	7.1	48	Yes	
6	2.2		110	11.7	7.2	51	Yes	
7	1.8		90	11.2	7.2	49	Yes	
8	1.9		95	12.3	7.2	50	Yes	
9	2.8		140	11.7	7.3	54	Yes	
10	2.1		105	14.4	7.2	51	Yes	
11	2.3		115	13.4	7.2	52	Yes	
12	1.8		90	13.4	6.9	41	Yes	
13	2.6		130	12.0	7.0	44	Yes	
14	2.1		105	11.4	7.0	42	Yes	
15	2.1		105	10.8	7.0	42	Yes	
16	1.3		65	12.9	6.9	39	Yes	
17	2.5		125	10.4	6.9	44	Yes	
18	2.1		105	11.3	6.9	42	Yes	
19	2.1		105	12.6	6.8	42	Yes	
20	2.0		100	13.0	6.9	41	Yes	
21	0.9		45	12.9	6.9	37	Yes	
22	3.1		155	10.9	6.9	46	Yes	
23	2.2		110	11.0	6.9	42	Yes	
24	2.3		115	9.9	7.0	43	Yes	
25	2.9		145	9.9	7.0	46	Yes	
26	2.0		100	11.0	7.0	41	Yes	
27	2.3		115	10.9	6.9	43	Yes	
28	2.6		130	11.3	7.0	44	Yes	
29								
30								
31		↓						↓

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2019