

OHA - Drinking Water Program -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

Douglas

Month/Year:

Jan 2025

System Name:	Peel Country Store		ID#:	4 PM	8 PM	WTP : TP - A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	[NTU]	Highest Reading of the Day ¹ [NTU]
1			0.135			0.135
2			0.155		0.120	0.155
3			0.234			0.234
4			0.262			0.262
5			0.097		0.110	0.110
6		0.065				0.065
7			0.190			0.190
8			0.140		0.114	0.140
9			0.075		0.062	0.075
10			0.059		0.079	0.079
11			0.055		0.066	0.066
12			0.059		0.095	0.095
13			0.061			0.135
14			0.095			0.095
15		0.049				0.060
16		0.059				0.225
17			0.150			0.150
18			0.085			0.085
19			0.087			0.087
20			0.073			0.073
21			0.059			0.059
22			0.066		0.064	0.066
23		0.064				0.064
24		0.062				0.062
25			0.064			0.064
26			0.067			0.067
27		0.069				0.069
28		0.063				0.063
29		0.060				0.060
30		0.064				0.064
31		0.061				0.061

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?

 Yes / NoCT's met everyday?
(see back)All Cl2 residual at entry point
≥ 0.2 mg/l?

All 4-hour turbidity readings ≤ 1 NTU?


 Yes / No Yes / No Yes / No

All turbidity reading <IFE 2 triggers

 Yes / No

Notes:

PRINTED NAME: Jeremy Schub

SIGNATURE: 

DATE: 2-4-25

PHONE #: 503-830-1680

CERT #: 09180

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	Peel Country Store	ID#:	41	94255	Month/Year:	Jan 2025	WTP - :	A
							Disinfection Giardia Log Inactiv:	1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.0	50	100	10.2	6.2	35	Yes	25
2	2.3	1	115	10.7	6.3	36	Yes	1
3	1.4		70	11.4	6.3	33	Yes	
4	2.2		110	11.0	6.2	35	Yes	
5	1.7		85	11.0	6.1	34	Yes	
6	1.6		80	11.4	6.1	33	Yes	
7	1.9		95	9.8	6.2	35	Yes	
8	1.9		95	9.8	6.3	35	Yes	
9	1.9		95	9.5	6.2	35	Yes	
10	1.5		75	9.8	6.3	33	Yes	
11	1.3		90	10.1	6.3	34	Yes	
12	1.8		90	8.9	6.3	45	Yes	
13	1.9		95	9.1	6.3	46	Yes	
14	1.7		85	8.7	6.4	45	Yes	
15	1.9		95	9.5	6.4	35	Yes	
16	2.0		100	8.5	7.0	55	Yes	
17	1.8		90	9.0	7.1	65	Yes	
18	1.8		90	8.6	7.1	65	Yes	
19	2.0		100	8.1	7.1	67	Yes	
20	2.1		105	8.2	7.2	68	Yes	
21	1.7		85	7.6	7.1	65	Yes	
22	2.1		105	7.5	7.1	68	Yes	
23	2.1		105	7.1	7.1	68	Yes	
24	2.0		100	8.2	7.1	67	Yes	
25	2.1		105	6.7	7.2	68	Yes	
26	2.1		105	5.5	7.1	68	Yes	
27	2.7		135	6.0	7.2	72	Yes	
28	2.3		115	6.3	7.3	70	Yes	
29	2.3		115	6.9	7.2	70	Yes	
30	1.9		95	6.8	7.1	67	Yes	
31	1.9		95	7.6	7.2	67	Yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.