

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: April 2025

System Name:	Peel Country Store			ID#: 41	94255	WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.175				0.175
2			0.125				0.125
3			0.125				0.125
4			0.102				0.102
5			0.082				0.082
6			0.087		0.075		0.087
7		0.210					0.210
8		0.229					0.229
9			0.085			0.060	0.085
10			0.075				0.075
11			0.091				0.091
12			0.064				0.064
13			0.064				0.064
14		0.065					0.065
15			0.069				0.069
16			0.074				0.074
17		0.063					0.063
18			0.066				0.066
19			0.069				0.069
20			0.075				0.075
21			0.075				0.075
22			0.068				0.068
23			0.035				0.035
24			0.076				0.076
25				0.079			0.079
26			0.093				0.093
27			0.066				0.066
28		0.063					0.063
29		0.062					0.062
30		0.060					0.060
31							

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?☒ Yes / NoAll 4-hour turbidity readings $\leq$ 1 NTU?☒ Yes / No

All turbidity reading < IFE 2 triggers

☒ Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)☒ Yes / NoAll Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?☒ Yes / No

Notes:

PRINTED NAME: Jeremy Schwab

SIGNATURE: *Jeremy L Schwab*

DATE: 5-9-25

PHONE #: 503-310-1680

CERT #: 09180

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	Peel Country Store	ID#: 41	94255	Month/Year: April 2025	WTP - : A	Disinfection Giardia Log Inactiv: 1
--------------	--------------------	---------	-------	------------------------	-----------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.8	50	90	10.8	6.5	34	Yes	25
2	2.0		100	11.3	6.6	41	Yes	
3	1.9		95	11.4	6.5	35	Yes	
4	2.0		100	10.4	6.6	41	Yes	
5	1.8		90	10.9	6.6	41	Yes	
6	1.8		90	12.4	6.6	41	Yes	
7	1.7		85	12.8	6.6	41	Yes	
8	1.9		95	11.1	6.6	41	Yes	
9	1.4		70	13.1	6.5	33	Yes	
10	1.7		85	11.9	6.6	41	Yes	
11	2.0		100	12.0	6.6	41	Yes	
12	2.1		105	12.0	6.6	42	Yes	
13	2.2		110	10.7	6.6	42	Yes	
14	1.8		90	11.3	6.6	41	Yes	
15	1.9		95	12.0	6.7	41	Yes	
16	1.8		90	11.8	6.7	41	Yes	
17	1.8		90	12.1	6.7	41	Yes	
18	2.0		100	11.6	6.7	41	Yes	
19	1.8		90	12.2	6.6	41	Yes	
20	2.0		100	11.8	6.7	41	Yes	
21	2.1		105	11.8	6.7	42	Yes	
22	1.8		90	11.2	6.6	41	Yes	
23	2.2		110	11.3	6.7	42	Yes	
24	2.0		100	11.7	6.7	41	Yes	
25	1.7		85	12.1	6.7	41	Yes	
26	2.4		120	12.2	6.7	43	Yes	
27	1.8		90	12.1	6.6	41	Yes	
28	1.8		90	12.3	6.6	41	Yes	
29	1.8		90	12.6	6.6	41	Yes	
30	1.8	↓	90	12.3	6.7	41	Yes	↓
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.