

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: May 2025

System Name:	Peel Country Store	ID#: 41	94255	WTP: TP -	A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	1 PM [NTU]	3 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1		0.067					0.067
2			0.065				0.065
3			0.075				0.075
4			0.073				0.073
5		0.091					0.091
6		0.062	0.076				0.076
7		0.062					0.062
8			0.061				0.061
9		0.067					0.067
10			0.062				0.062
11			0.062				0.062
12		0.068					0.068
13		0.082					0.082
14		0.067					0.067
15			0.068				0.068
16			0.066				0.066
17		0.068					0.068
18			0.075				0.075
19		0.071					0.071
20		0.073					0.073
21		0.065					0.065
22		0.066					0.066
23			0.068				0.068
24			0.067				0.067
25			0.066				0.066
26			0.062				0.062
27		0.065					0.065
28		0.063					0.063
29		0.066					0.066
30			0.068				0.068
31			0.068				0.068

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes/No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes/No

All turbidity reading < IFE 2 triggers

Yes/No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes/No

All Cl2 residual at entry point
 $\geq$ 0.2 mg/l?

Yes/No

Notes:

PRINTED NAME: Jeremy L Schwab

SIGNATURE: *Jeremy L Schwab*

DATE: 6-9-25

PHONE #: 503-310-1680

CERT #: 09180

¹ Including continuous NTU data. If applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Peel Country Store	ID#: 41	94255	Month/Year: May 2025	WTP - : A	Disinfection Giardia Log Inactiv: 1
---------------------------------	---------	-------	----------------------	-----------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.0	50	100	12.3	6.7	41	Yes	25
2	2.2		110	13.1	6.6	42	Yes	
3	1.8		90	13.1	6.7	41	Yes	
4	1.6		80	11.4	6.7	40	Yes	
5	1.9		95	11.6	6.7	41	Yes	
6	1.9		95	12.4	6.7	41	Yes	
7	1.8		90	13.1	6.7	41	Yes	
8	1.9		95	13.8	6.7	41	Yes	
9	1.7		85	13.4	6.7	41	Yes	
10	1.8		90	13.4	6.7	41	Yes	
11	1.9		95	13.6	6.7	41	Yes	
12	1.4		70	13.4	6.6	39	Yes	
13	1.1		55	12.6	6.6	38	Yes	
14	1.5		75	12.6	6.6	40	Yes	
15	1.7		85	12.4	6.6	41	Yes	
16	1.4		70	12.7	6.6	39	Yes	
17	1.4		70	13.9	6.6	39	Yes	
18	1.4		70	13.1	6.6	39	Yes	
19	1.6		80	13.1	6.6	40	Yes	
20	1.1		55	13.3	6.6	38	Yes	
21	1.6		80	12.3	6.6	40	Yes	
22	1.7		85	13.3	6.6	41	Yes	
23	1.8		90	12.6	6.7	41	Yes	
24	1.6		80	12.3	6.6	40	Yes	
25	1.5		75	13.5	6.6	40	Yes	
26	1.6		80	13.6	6.6	40	Yes	
27	2.0		100	13.8	6.7	41	Yes	
28	2.2		110	14.9	6.6	28	Yes	
29	2.5		125	14.7	6.7	29	Yes	
30	2.5		125	14.7	6.7	29	Yes	
31	2.1		105	14.8	6.7	28	Yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.