

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: June 2025

System Name:	Peel Country Store		ID#: 41	94255	WTP: TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.076				0.076
2		0.074					0.074
3		0.083					0.083
4		0.124					0.124
5			0.075				0.075
6			0.065				0.065
7			0.072				0.072
8			0.062				0.062
9		0.070					0.070
10		0.065					0.065
11		0.064					0.064
12		0.064					0.064
13			0.064				0.064
14			0.069				0.069
15			0.062				0.062
16		0.088					0.088
17		0.076					0.076
18		0.074					0.074
19		0.076 0.070 WR					0.070
20		0.086					0.086
21			0.105				0.105
22			0.081				0.081
23		0.077					0.077
24		0.074					0.074
25		0.064					0.064
26		0.066					0.066
27		0.060					0.060
28			0.065				0.065
29			0.110				0.110
30			0.092				0.092
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
All turbidity reading < IFE 2 triggers	☒ Yes / No		
Notes:		PRINTED NAME: JEREMY SCHWAB SIGNATURE: <i>Jeremy L Schwab</i> PHONE #: 503-310-1680	
		DATE: 7-2-25 CERT #: 09180	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Peel Country Store		ID#: 41	94255	Month/Year: June 2025	WTP -: A	Disinfection Giardia Log Inactiv: 1
---------------------------------	--	---------	-------	-----------------------	----------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.9	50	95	14.7	6.7	28	Yes	25
2	1.9		95	14.3	6.5	35	Yes	
3	1.0		50	14.0	6.5	31	Yes	
4	1.8		90	16.5	6.7	27	Yes	
5	1.8		90	14.6	6.5	23	Yes	
6	2.1		105	14.7	6.5	23	Yes	
7	2.0		100	15.7	6.5	23	Yes	
8	1.9		95	16.6	6.5	23	Yes	
9	1.9		95	17.9	6.4	23	Yes	
10	2.2		110	18.6	6.4	23	Yes	
11	1.5		75	16.9	6.4	22	Yes	
12	1.8		90	15.9	6.5	23	Yes	
13	2.0		100	15.6	6.4	23	Yes	
14	2.2		110	14.3	6.5	35	Yes	
15	2.0		100	13.8	6.4	35	Yes	
16	2.0		100	15.1	6.4	23	Yes	
17	1.8		90	14.5	6.4	23	Yes	
18	1.7		85	15.3	6.4	23	Yes	
19	2.0		100	15.4	6.4	23	Yes	
20	2.0		100	15.0	6.4	23	Yes	
21	1.8		90	14.1	6.4	34	Yes	
22	1.6		80	14.1	6.4	33	Yes	
23	1.7		85	14.4	6.4	34	Yes	
24	1.6		80	15.5	6.4	22	Yes	
25	2.1		105	15.7	6.5	23	Yes	
26	2.0		100	15.8	6.5	23	Yes	
27	2.0		100	16.1	6.4	23	Yes	
28	1.8		90	16.2	6.5	23	Yes	
29	2.3		115	16.1	6.5	29	Yes	
30	2.4	↓	120	16.4	6.4	29	Yes	↓
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.