

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: July 2025

System Name:		Peel Country Store		ID#: 41	94255	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.098				0.098
2			0.078				0.078
3			0.083				0.083
4			0.082				0.082
5			0.072				0.072
6			0.072				0.072
7			0.092				0.092
8			0.099				0.099
9			0.061				0.061
10			0.098				0.098
11				0.083			0.083
12			0.078				0.078
13			0.086				0.086
14		0.085					0.085
15		0.080					0.080
16		0.086					0.086
17		0.068					0.068
18			0.073				0.073
19			0.073				0.073
20			0.081				0.081
21		0.071					0.071
22		0.069					0.069
23		0.066					0.066
24		0.074					0.074
25		0.076					0.076
26			0.227			0.275	0.275
27			0.248	0.180		0.135	0.248
28		0.104					0.104
29					0.089		0.089
30			0.082				0.082
31				0.096			0.096

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity reading < IFE 2 triggers	Yes / No		
Notes:		PRINTED NAME: Jeremy Schwab SIGNATURE: <i>Jeremy L. Schwab</i> PHONE #: 503-310-1680 DATE: 8-6-25 CERT #: 09180	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:

Peel Country Store

ID#: 41

94255

Month/Year:

July 2015

Disinfection Giardia

Log Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	2.1	50	105	19	6.9	28	yes	25
2	1.9		95	19	7.0	28	yes	↑
3	2.0		100	19	6.9	28	yes	
4	1.6		80	19	6.9	26	yes	
5	2.5		125	18	7.0	29	yes	
6	2.3		115	18	6.8	29	yes	
7	2.4		120	19	7.0	29	yes	
8	2.0		100	18	7.0	28	yes	
9	1.9		95	19	7.1	33	yes	
10	1.6		80	19	6.7	26	yes	
11	2.0		100	19	6.8	28	yes	
12	1.6		80	18	6.5	22	yes	
13	1.8		90	19	6.5	23	yes	
14	1.6		80	20	6.5	17	yes	
15	1.9		95	19	6.5	23	yes	
16	1.7		85	19	6.5	23	yes	
17	1.2		60	19	6.4	21	yes	
18	1.5		75	18	6.5	22	yes	
19	1.6		80	17	6.5	22	yes	
20	1.7		85	18	6.4	23	yes	
21	1.6		80	18	6.3	22	yes	
22	1.5		75	17	6.4	22	yes	
23	1.7		85	18	6.3	23	yes	
24	1.6		80	19	6.3	22	yes	
25	1.6		80	18	6.3	22	yes	
26	1.5		75	17	6.4	22	yes	
27	1.3		65	17	6.4	22	yes	
28	1.3		65	18	6.3	22	yes	
29	1.3		65	17	6.5	22	yes	
30	0.9		45	18	6.5	21	yes	✓
31	0.8		40	18	6.7	24	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.