

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: August 2025

System Name:	Peel Country Store			ID#: 41	94255	WTP: TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				0.082			0.082
2			0.078				0.078
3			0.098				0.098
4			0.080				0.080
5			0.073				0.073
6					0.078		0.078
7		0.091					0.091
8		0.288					0.288
9			0.154				0.154
10			0.098				0.098
11		0.079					0.079
12		0.075					0.075
13		0.068					0.068
14		0.068					0.068
15			0.067				0.067
16			0.138				0.138
17		0.067					0.067
18		0.069					0.069
19			0.071				0.071
20			0.077				0.077
21			0.140				0.140
22			0.110				0.110
23			0.108				0.108
24			0.093				0.093
25		0.105					0.105
26		0.088					0.088
27		0.090					0.090
28			0.079				0.079
29			0.086				0.086
30			0.099				0.099
31			0.080				0.080

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes / No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes / No

All turbidity reading $<$ IFE 2 triggers

Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point
 $\geq$ 0.2 mg/l?

Yes / No

Notes:

PRINTED NAME: Jeremy Schwab

SIGNATURE: [Signature]

DATE: 9-8-25

PHONE #: 503 340 1480

CERT #: 09180

¹ Including continuous NTU data. If applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effic. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Peel Country Store	ID#: 41	94255	Month/Year: August 2025	WTP - : A
Disinfection Giardia Log Inactiv: 1				

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.3	50	65	19	6.6	22	yes	25
2	0.9		45	19	6.7	25	yes	
3	0.9		45	18	6.7	25	yes	
4	0.9		45	18	6.6	25	yes	
5	1.5		25	18	6.5	22	yes	
6	1.2		60	18	6.8	25	yes	
7	2.6		130	19	6.9	29	yes	
8	1.1		55	17	6.8	25	yes	
9	1.6		80	16	6.8	26	yes	
10	1.6		80	17	6.9	26	yes	
11	1.7		85	19	6.7	27	yes	
12	1.6		80	20	6.7	20	yes	
13	1.7		85	20	6.7	20	yes	
14	1.6		80	20	6.8	20	yes	
15	1.7		85	18	6.8	27	yes	
16	1.2		60	20	6.7	19	yes	
17	2.0		100	19	6.8	28	yes	
18	1.7		85	19	6.7	27	yes	
19	1.7		85	17	6.7	27	yes	
20	1.9		95	17	6.8	28	yes	
21	1.7		85	17	6.9	27	yes	
22	1.2		60	18	6.8	25	yes	
23	1.9		95	18	6.8	28	yes	
24	1.8		90	20	6.7	20	yes	
25	1.9		95	21	6.8	21	yes	
26	1.7		85	20	6.7	20	yes	
27	1.8		90	20	6.8	20	yes	
28	1.8		90	19	6.8	27	yes	
29	1.7		85	18	7.0	27	yes	
30	1.7		85	18	6.7	27	yes	
31	0.9		45	18	6.6	25	yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.