


OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas
Month/Year: Sept. 2025

System Name:		Peel Country Store		ID#: 41	94255	WTP: TP -		A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1			0.070				0.070	
2			0.084				0.084	
3			0.081				0.081	
4			0.084				0.084	
5			0.079				0.079	
6			0.081				0.081	
7		WK		0.120			0.120	
8		0.220					0.220	
9		0.166					0.166	
10		0.110					0.110	
11		0.085					0.085	
12		0.085					0.085	
13			0.085				0.085	
14			0.082				0.082	
15		0.100					0.100	
16		0.087					0.087	
17		0.081					0.081	
18			0.078				0.078	
19		0.072					0.072	
20			0.070				0.070	
21					0.069		0.069	
22		0.066					0.066	
23		0.082					0.082	
24		0.076					0.076	
25		0.068					0.068	
26			0.074				0.074	
27			0.082				0.082	
28				0.110			0.110	
29		0.075					0.075	
30		0.072					0.072	
31								

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity reading < IFE 2 triggers	☒ Yes / ☐ No		
Notes:		PRINTED NAME: Jeremy Schwind SIGNATURE:  PHONE #: 503-310-1680 DATE: 10-7-25 CERT #: 09180	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	Peel Country Store	ID#: 41	94255	Month/Year: Sept. 2025	WTP - : A	Disinfection Giardia Log Inactiv: 1
--------------	--------------------	---------	-------	------------------------	-----------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.0	50	100	18	6.6	28	Yes	25
2	2.3		115	18	6.6	29	Yes	
3	1.7		85	19	6.6	27	Yes	
4	1.8		90	19	6.6	27	Yes	
5	1.7		85	19	6.7	27	Yes	
6	1.9		95	19	6.7	28	Yes	
7	1.7		85	19	6.7	27	Yes	
8	1.4		70	18	6.7	26	Yes	
9	1.5		75	18	6.7	26	Yes	
10	1.3		65	18	6.7	26	Yes	
11	1.7		85	18	6.7	27	Yes	
12	1.5		75	18	6.7	26	Yes	
13	1.9		95	16	6.7	28	Yes	
14	1.9		95	18	6.7	28	Yes	
15	2.1		105	17	6.7	28	Yes	
16	1.9		95	16	6.7	28	Yes	
17	2.2		110	17	6.7	28	Yes	
18	2.0		100	17	6.7	28	Yes	
19	2.5		125	17	6.7	29	Yes	
20	2.2		110	17	6.8	28	Yes	
21	1.9		95	17	6.6	28	Yes	
22	1.7		85	16	6.7	27	Yes	
23	1.8		90	15	6.7	27	Yes	
24	1.6		80	16	6.7	26	Yes	
25	2.1		105	16	6.7	28	Yes	
26	1.9		95	15	6.7	28	Yes	
27	1.8		90	14	6.7	41	Yes	
28	1.8		90	15	6.8	27	Yes	
29	1.8		90	16	6.6	27	Yes	
30	1.6	✓	80	15	6.6	26	Yes	
31								✓

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.