

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Nov. 2025

System Name:	Peel Country Store			ID#: 41	94255	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.090				0.090
2			0.085				0.085
3			0.090				0.090
4			0.084				0.084
5			0.095				0.095
6			0.102				0.102
7			0.290				0.290
8			0.088				0.088
9			0.083				0.083
10			0.095				0.095
11			0.088				0.088
12			0.083				0.083
13			0.086				0.086
14			0.092				0.092
15			0.093				0.093
16			0.095				0.095
17		0.275			0.205		0.275
18		0.083					0.083
19		0.085					0.085
20		0.098					0.098
21			0.084				0.084
22			0.091				0.091
23			0.081				0.081
24		0.097					0.097
25		0.100					0.100
26		0.085					0.085
27			0.085				0.085
28			0.082				0.082
29		0.125					0.125
30				0.100			0.100
31							

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

(Yes) / No

All 4-hour turbidity readings $\leq$ 1 NTU?

(Yes) / No

All turbidity reading < IFE 2 triggers

(Yes) / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

(Yes) / No

All Cl2 residual at entry point
 $\geq$ 0.2 mg/l?

(Yes) / No

Notes:

PRINTED NAME: Jeremy Schukib

SIGNATURE: *Jeremy Schukib*

DATE: 12-9-25

PHONE #: 503-310-1680

CERT #: 09180

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

Peel Country Store

ID#: 41

94255

Month/Year: NOV. 2025

Disinfection *Giardia*
Log Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.6	50	80	13	6.6	40	Yes	25
2	1.6		80	13	6.7	40	Yes	
3	1.7		85	13	6.6	41	Yes	
4	1.6		80	13	6.6	40	Yes	
5	1.5		75	13	6.6	40	Yes	
6	1.7		85	13	6.7	41	Yes	
7	1.4		70	13	6.7	39	Yes	
8	1.6		80	12	6.7	40	Yes	
9	1.9		95	12	6.7	41	Yes	
10	1.5		75	12	6.7	40	Yes	
11	1.5		75	12	6.7	40	Yes	
12	1.8		90	13	6.7	41	Yes	
13	2.0		100	13	6.7	41	Yes	
14	1.6		80	13	6.8	40	Yes	
15	1.5		75	13	6.7	40	Yes	
16	1.6		80	12	6.7	40	Yes	
17	1.0		50	13	6.8	37	Yes	
18	1.3		65	13	6.8	39	Yes	
19	1.6		80	12	6.7	40	Yes	
20	1.8		90	12	6.8	41	Yes	
21	1.8		90	11	6.8	41	Yes	
22	2.1		105	11	6.7	42	Yes	
23	2.1		105	11	6.8	42	Yes	
24	1.5		75	11	6.8	40	Yes	
25	1.6		80	11	6.8	40	Yes	
26	1.9		95	12	6.8	41	Yes	
27	1.9		95	11	6.8	41	Yes	
28	1.9		95	12	6.8	41	Yes	
29	1.8		90	12	6.7	41	Yes	
30	2.0	↓	100	12	6.7	41	Yes	↓
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.