

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Dec. 2025

System Name:	Peel Country Store	ID#: 41	94255	WTP: TP -	A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1		0.099					0.099
2		0.087					0.087
3		0.077					0.077
4		0.070					0.070
5			0.071				0.071
6					0.175		0.175
7				0.086			0.086
8		0.083					0.083
9		0.075					0.075
10			0.135				0.135
11		0.125					0.125
12			0.096				0.096
13				0.101			0.101
14				0.104			0.104
15		0.110					0.110
16		0.240				0.098	0.240
17		0.275					0.275
18			0.079				0.079
19			0.280				0.280
20			0.125				0.125
21			0.074				0.074
22		0.225			0.145		0.225
23			0.175				0.175
24			0.240				0.240
25			0.234				0.234
26			0.102				0.102
27			0.096				0.096
28			0.091				0.091
29		0.099					0.099
30		0.110					0.110
31		0.103					0.103

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?

Yes/No

All 4-hour turbidity readings $\leq$ 1 NTU?

Yes/No

All turbidity reading < IFE 2 triggers

Yes/No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

Yes/No

All Cl2 residual at entry point
 $\geq$ 0.2 mg/l?

Yes/No

Notes:

PRINTED NAME: Jeremy Schwab

SIGNATURE: *Jeremy Schwab*

DATE: 1-6-26

PHONE #: 503-810-1690

CERT #: 09180

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Peel Country Store		ID#: 41	94255	Month/Year: Dec 2025	WTP - : A	Disinfection Giardia Log Inactiv: 1
---------------------------------	--	---------	-------	----------------------	-----------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.1	30	105	11	6.7	42	Yes	25
2	1.8		90	11	6.7	41	Yes	
3	2.0		100	11	6.7	41	Yes	
4	2.2		110	11	6.8	42	Yes	
5	1.7		85	12	6.7	41	Yes	
6	1.5		75	13	6.6	40	Yes	
7	1.9		95	12	6.7	41	Yes	
8	1.7		85	12	6.7	41	Yes	
9	1.9		95	13	6.7	41	Yes	
10	2.4		120	13	6.7	43	Yes	
11	2.2		110	13	6.7	42	Yes	
12	2.2		110	11	6.7	42	Yes	
13	2.3		115	11	6.8	43	Yes	
14	2.1		105	11	6.8	42	Yes	
15	2.0		100	12	6.8	41	Yes	
16	2.0		100	13	6.8	41	Yes	
17	1.5		75	13	6.7	40	Yes	
18	1.8		90	12	6.8	41	Yes	
19	1.9		95	13	6.8	41	Yes	
20	1.4		70	12	6.5	33	Yes	
21	1.3		65	12	6.8	39	Yes	
22	1.6		80	12	6.8	40	Yes	
23	1.7		85	12	6.9	41	Yes	
24	1.7		85	12	6.9	41	Yes	
25	1.7		85	12	6.9	41	Yes	
26	1.9		95	11	6.9	41	Yes	
27	2.1		105	12	6.9	42	Yes	
28	2.0		100	11	6.9	41	Yes	
29	2.1		105	11	6.9	42	Yes	
30	2.0		100	10	6.9	41	Yes	
31	1.8	✓	90	10	6.9	41	Yes	✓

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.