

OHA - Drinking Water Program -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Douglas
 Month/Year: Jan 2026

System Name:	Peel Country Store		ID#: 41	94255	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			0.103				0.103
2			0.127				0.127
3			0.095				0.095
4				0.110			0.110
5		0.113					0.113
6		0.120					0.120
7		0.107					0.107
8		0.122					0.122
9			0.225				0.225
10			0.098				0.098
11				0.102			0.102
12		0.121					0.121
13		0.102					0.102
14		0.090					0.090
15		0.082					0.082
16		0.085					0.085
17			0.102				0.102
18			0.089				0.089
19			0.098				0.098
20		0.112					0.112
21		0.113					0.113
22		0.115					0.115
23			0.092				0.092
24			0.094				0.094
25				0.093			0.093
26		0.099					0.099
27		0.089					0.089
28		0.086					0.086
29		0.096					0.096
30		0.087					0.087
31			0.096				0.096

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity reading < IFE 2 triggers <input checked="" type="radio"/> Yes / No		

Notes:	PRINTED NAME: <u>Jeremy Schwab</u>
	SIGNATURE: <u>Jeremy Schwab</u> DATE: <u>2-8-26</u>
	PHONE #: <u>503-310-1680</u> CERT #: <u>09180</u>

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Peel Country Store	ID#: 41	94255	Month/Year: Jan 2026	WTP - : A	Disinfection Giardia Log Inactiv: 1
---------------------------------	---------	-------	----------------------	-----------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.8	50	90	12	6.9	41	Yes	25
2	2.1		105	12	6.8	42	Yes	
3	2.1		105	12	6.8	42	Yes	
4	2.0		100	12	6.8	41	Yes	
5	2.0		100	12	6.8	41	Yes	
6	2.1		105	12	6.8	42	Yes	
7	2.1		105	11	6.8	42	Yes	
8	1.6		80	11	6.8	40	Yes	
9	1.7 2.0 ^{WK}		85 100 ^{WK}	11	6.8	41	Yes	
10	2.0		100	11	6.8	41	Yes	
11	1.8		90	11	6.7	41	Yes	
12	2.0		100	11	6.8	41	Yes	
13	2.0		100	10	6.9	41	Yes	
14	2.2		110	10	6.9	42	Yes	
15	2.3		115	11	6.9	43	Yes	
16	1.9		95	9	6.9	55	Yes	
17	1.9		95	9	6.9	55	Yes	
18	1.7		85	9	6.9	54	Yes	
19	2.3		115	9	6.9	57	Yes	
20	2.0		100	8	6.9	55	Yes	
21	2.0		100	9	6.9	55	Yes	
22	2.1		105	9	6.9	56	Yes	
23	1.9		95	9	6.9	55	Yes	
24	2.2		110	8	6.9	56	Yes	
25	1.8		90	7	6.9	54	Yes	
26	1.8		90	8	6.9	54	Yes	
27	1.9		95	9	6.9	55	Yes	
28	2.0		100	10	6.9	41	Yes	
29	2.1		105	11	6.9	42	Yes	
30	1.8	↓	90	11	6.9	41	Yes	↓
31	2.0		100	10	6.9	41	Yes	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.